

ADDENDA TO SPECIFICATIONS FOR GENERAL WORK:CONCRETE WORK:

All interior cement stairs and landings (except in Concourse #19) shall have a sanitary cement base. Base shall be 6" high coved into treads and stopped at top against a metal ground or bead furnished and set by this contractor. Cement mortar for base shall be as specified under "Cement Finish" and metal ground or bead shall be selected by the Architect. All lines and contours shall be straight and true and all work shall be done in a skilful manner of the same standard as specified for cement finish and to the entire satisfaction of the Architect.

Install into exterior cement steps of West Entrance to Mezzanine floor, "Mason" safety treads as specified for interior cement stairs.