



AN ABSTRACT OF THE THESIS OF

Katharine Danielle Sarmast for the degree of Master of Science in Radiation Health Physics presented on November 19, 2010.

Title: MCNP5 Modeling of the Oregon State TRIGA<sup>®</sup> Reactor for SkyShine Dose Estimation After a Loss of Coolant Accident

Abstract approved:

---

Steve R. Reese

This thesis evaluates dose rates from the TRIGA<sup>®</sup> reactor by comparing ion chamber measured exposure rates to exposure rates calculated from MCNP5 model data. The first step evaluates the energy distribution required to match ion chamber exposure rates from measurements taken at 1 foot increments above the reactor core. Next, the back calculated source activity is used to determine the exposure rates, at those same 1 ft increments above the core, in the event of a loss of coolant accident (LOCA). Then the energies deposited in simulated ion chambers, above the core are used to determine the dose rate to a person standing on top of the reactor bioshield after a LOCA. The dose rates that are calculated using the MCNP5 data were compared to calculations from the Oregon State TRIGA<sup>®</sup> Reactor (OSTR) Safety Analysis Report (SAR). The final step is to determine the maximum dose rate at the OSTR facility perimeter after a LOCA, due to skyshine.

The MCNP5 results showed that OSTR SAR overestimates dose rates at the top of the reactor bioshield. The discrepancy stems from the OSTR SAR using worst case scenario data, while this report uses less conservative, yet accurate, assumptions. The instantaneous dose rates on the reactor building exterior from photon skyshine peak at approximately 30 mrem per hour. The integrated activity resulted in a dose rate of approximately .005 mrem within the first hour after the reactor has shut down.

©Copyright by Katharine Danielle Sarmast

November 19, 2010

All Rights Reserved

MCNP5 Modeling of the Oregon State TRIGA® Reactor for SkyShine Dose Estimation  
After a Loss of Coolant Accident

By

Katharine Danielle Sarmast

A THESIS

Submitted to

Oregon State University

in partial fulfillment of  
the requirements for the  
degree of

Master of Science

Presented November 19, 2010  
Commencement June 2011

Master of Science thesis of Katharine Danielle Sarmast presented on November 19, 2010.

APPROVED:

---

Major Professor, Representing Radiation Health Physics

---

Head of the Department of Nuclear Engineering and Radiation Health Physics

---

Dean of the Graduate School

I understand that my thesis will become part of the permanent collection of Oregon State University libraries. My signature below authorizes release of my thesis to any reader upon request.

---

Katharine Danielle Sarmast, Author

## ACKNOWLEDGEMENTS

I would like to express my tremendous gratitude to all faculty and staff in the Nuclear Engineering and Radiation Health Physics department at Oregon State University. A special thank you goes to Dr. Steve Reese, whose assistance and guidance enabled me to complete my thesis topic. His patience is endless, and for that I am forever grateful.

I would also like to thank my family: my father Dan, who has taught me most of life's lessons; my sister Patricia and her family, who have encouraged me to get out and try different things; many other family and friends who are endless in their love and support. You are all such an integral part of my success and I love you all!

Special thanks go to my supportive husband, Waqar. He supported my decision to continue my education by moving halfway across the country with me, allowing me to attend OSU as an on campus student. With his encouragement and love, I am moving forward into a promising and bright future.

## TABLE OF CONTENTS

	<u>Page</u>
1. Introduction .....	1
1.1 Research Objective .....	1
1.2 TRIGA® Reactors .....	1
1.2.1 TRIGA® Background .....	2
1.2.2 TRIGA® Fuel Design .....	3
2. Literature Review .....	4
3. Background Theory .....	7
3.1 Fission Theory .....	7
3.2 Fission Product Decay Activity .....	9
3.3 Electromagnetic Radiation.....	10
3.4 Shielding and Photon Interactions.....	11
3.4.1 Photoelectric Effect.....	12
3.4.2 Pair Production .....	13
3.4.3 Compton Scattering .....	13
3.4.4 Coherent Scattering .....	14
3.5 Ionization Chambers .....	14
3.6 Dose and Dose Equivalent .....	15
3.7 Skyshine .....	16
3.8 MCNP5 .....	16
4. Materials and Methods.....	17
4.1 Exposure Measurements .....	17
4.2 TRIGA Reactor Modeling.....	19
4.2.1 Material Specification .....	21
4.2.2 Tally Specification .....	21
4.2.3 Source Specification.....	22
5. Results.....	23

TABLE OF CONTENTS (Continued)

	<u>Page</u>
5.1 Exposure Rates – Monoenergetic Photons.....	23
5.2 Exposure Rates – Energy Distributions.....	32
5.3 Dose Calculation at the Reactor Top .....	35
5.4 Facility External Dose.....	38
6 Conclusion.....	40
6.1 Future Work.....	41
APPENDICES .....	44
A APPENDIX – MCNP5 INPUT FOR LOCA SIMULATION .....	45
B APPENDIX – PARTIAL MCNP5 OUTPUT FOR LOCA SIMULATION; MeV/photon .....	63



## LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1. Side View of a TRIGA® Mark II reactor.....	3
2. Uranium 235 Fission yield vs. mass number.....	8
3. Fission fragment instability diagram.....	9
4. Fission product activity as a function of time after OSTR shutdown. ....	10
5. Electromagnetic energy spectrum.....	11
6. Ion chamber placement above reactor core. ....	18
7. Side Vertical view of the OSTR model.....	20
8. Top view of the OSTR model.....	20
9. Exposure rates calculated from MCNP5 results in water. ....	25
10. Exposure rates (R/h) at various heights above the TRIGA reactor core in air.....	27
11. Energy deposited by 1 MeV photons in a simulated ion chamber as a function of distance from the core.....	29
12. Energy deposited by 2 MeV photons in a simulated ion chamber as a function of distance from the core.....	29
13. Energy deposited by 3 MeV photons in a simulated ion chamber as a function of distance from the core.....	30
14. Energy deposited by 5 MeV photons in a simulated ion chamber as a function of distance from the core.....	30
15. Energy deposited by 5 MeV photons in a simulated ion chamber as a function of distance from the core.....	31
16. Energy deposited by 10 MeV photons in a simulated ion chamber as a function of distance from the core.....	31
17. Exposure rates (R/hr) from simulation 8 and measured values at various heights above the TRIGA reactor core.....	34
18. Fission product activity as a function of time after shutdown with activity calculated using Equation 7.....	36

LIST OF FIGURES (Continued)

<u>Figure</u>	<u>Page</u>
19. Corrected fission product activity.....	37
20. Dose rates external to OSTR from 0 to 100 cm in height. ....	39
21. Cell positions for photon dose rates in Figure 19.....	40

## LIST OF TABLES

<u>Table</u>	<u>Page</u>
1. Fission Product Activity and Source Flux After Shutdown from the OSTR SAR.....	5
2. Effective Dose Rates at Reactor Top after Shutdown from the OSTR SAR.....	6
3. Measured exposure rates at points above the OSTR. ....	18
4. Material compositions for MCNP5 model. ....	21
5. Initial photon energy values for MCNP5 simulations. ....	22
6. Source activity and calculated exposure rates for monoenergetic photon energies in water. ....	24
7. Source activity and calculated exposure rates for monoenergetic photon energies in air. ....	26
8. *F8 tally equivalent to the measured exposure values.....	28
9. Percent of initial particles to interact prior to intersection point. ....	32
10. Source activity and calculated exposure of simulation 8. ....	33
11. Simulated exposure levels for a LOCA at positions above the reactor core. ....	35
12. Exposure and dose rates after LOCA at the top of the TRIGA® bioshield. ....	38

## MCNP5 Modeling of the Oregon State TRIGA<sup>®</sup> Reactor for SkyShine Dose Estimation After a Loss of Coolant Accident

### 1. Introduction

#### 1.1 Research Objective

The objective of this thesis is to estimate photon dose rates, attributable to skyshine, from the Oregon State University TRIGA<sup>®</sup> reactor (OSTR) generated during a LOCA. Maximum dose rates in and around the reactor facility are achieved when the primary reactor water is removed or drained. A LOCA would be a scenario where the dose to workers and the public would be maximized.

Dose to workers and the public must not exceed limits set by the NRC for licensed activities. Regulations in 10 CFR 20 dictate dose limits allowable for radiation workers and members of the public from licensed activities. The dose to the public at facility boundaries should be less than 100 mrem in a year or 2 mrem in any one hour [1]. Modeling the OSTR with MCNP5 allows dose rates to be estimated in the event of a LOCA and benchmarked against values calculated in the OSTR SAR. The research will show that the dose rates are likely less than previously determined in the OSTR SAR.

#### 1.2 TRIGA<sup>®</sup> Reactors

The TRIGA<sup>®</sup> (Testing, Research, Isotope, General Atomic) reactor provides an invaluable tool for nuclear engineering and radiation health physics students to study and evaluate nuclear processes. The reactor is situated toward the western edge of the OSU campus in Corvallis, Oregon. The reactor is licensed by the Nuclear Regulatory Commission (NRC) to operate up to 1.1 MW, and contains low enriched uranium (LEU) fuel.

Nuclear reactor operation safety is an issue that arose before the very first nuclear reactor, the Chicago Pile, became critical on December 2<sup>nd</sup>, 1942 [2]. Since then, the need for scientists to have a tool to help understand a nuclear chain reaction and reactor control has increased considerably. Prior to the development of research

reactors training for operators and scientists was very theoretical, with rare chances for practical training. This need resulted in the development of a small, low power reactor “that is safe even in the hands of a young graduate student” [3] – the TRIGA® reactor.

A negative public perception of nuclear power, and radiation in general, requires the nuclear industry to be as faultless as possible in designs and operation. The inherent safety in the TRIGA® design removes some error associated with human intervention, and allows the reactor to power down in the event of mechanical system failure [4]. TRIGA® inherent safety is accomplished with a fuel design in which negative feedback occurs in the reactivity as temperature increases to safely shutdown the reactor.

### **1.2.1 TRIGA® Background**

TRIGA® reactors were developed by General Atomics as one of their initiatives to create peaceful uses for nuclear technology. The original TRIGA® Mark I was designed with graphite reflected core located in an open tank of water which was all placed underground. The OSTR is a Mark II version. The Mark II is similar to the Mark I in design except the water tank and core sit above ground and is surrounded by a concrete bioshield.

The core of the reactor sits below approximately 16 feet of water. Surrounding the core is an 8 inch graphite reflector also containing 2 inches of lead. Approximately 12 inches of water is followed by approximately 8 feet of the cement bioshield. The core consists of 87 LEU Uranium/Zirconium hydride fuel elements and 4 control rods in a circular grid array. Each fuel element has graphite reflectors at each end, and is surrounded by stainless steel cladding. The reactor operates at 1.1 MW, and can pulse up to approximately 2,000 MW [5]. Figure 1 shows a side view of OSTR.




Figure 1. Side View of a TRIGA® Mark II reactor [6].

### 1.2.2 TRIGA® Fuel Design

The fuel elements in the OSTR are composed of low enriched uranium in a zirconium hydride matrix. The fuel also includes a burnable poison, erbium. The erbium has a double resonance at approximately 0.5 eV. As the fuel temperature increases, the resonance cross section appears to spread out and cover a wider range of energy [7]. As the temperature and resonance increase, thermal flux is depressed and the net reactivity decreases. This process is called Doppler broadening and is useful for adding stability to core reactivity.

Reactivity, an indicator of how many neutrons are available for fission within a reactor core, is defined as:

$$\rho = [k(t) - 1]/k(t) \quad \text{Equation 1.}$$

where  $k$  is the time dependent multiplication factor [7]. If reactivity is less than zero, the core is subcritical and there are fewer neutrons in the following generation than the

previous. If reactivity is zero, there is one neutron produced from fission for every neutron in the previous generation and the reactor is critical. If reactivity is greater than zero, each neutron produces more than one neutron by fission and the reactor is supercritical. The amount of change in reactivity per change in degree of fuel temperature is the reactivity temperature coefficient:

$$\alpha = \frac{(\delta p / \delta T)}{p} \quad \text{Equation 2.}$$

where  $p$  is the reactivity and  $T$  is the temperature. Reactors are required by the general design criterion of the Nuclear Regulatory Commission (NRC) to utilize a negative temperature coefficient within the power operating range [8].

The effect of the negative coefficient is that as the fuel heats up, the number of neutrons produced from each generation is reduced. The inherently safe design attained with a negative temperature coefficient is achieved by use of hydrogen moderator and erbium poison integrated within the fuel elements of TRIGA<sup>®</sup> reactors. In TRIGA<sup>®</sup> reactors the negative temperature coefficient of the fuel will prevent further temperature increasing and ultimate meltdown. Although a LOCA will not result in fuel melting, the core would be uncovered creating a significant source term.

## 2. Literature Review

An analysis of the dose rate produced above the core as a result of a LOCA was performed in the OSTR SAR [9]. Two scenarios for LOCA were considered: 1) water pumped from the reactor tank and 2) reactor tank failure. The final determination was that the pump configuration for the OSTR could not result in complete loss of water from the tank. The water pump return pipe is above the top of the reactor core and will not drain water below the level of the reactor core. Thus, a reactor tank failure would be the main consideration for a LOCA.

Reactor tank failure could be caused by corrosion or mechanical failure of a joint on the reactor or an attached piping system. However, in the case of corrosion, the

leaks would be noticeable, and would undergo timely repair or an addition of water to the system to compensate for primary water loss. Mechanical failure could lead to extreme and irreversible loss of primary coolant from the reactor core. This could be caused by a sizeable object falling into the tank and irreparably damaging the tank wall, or the remote possibility of structural damage caused by an earthquake.

Once the core is uncovered there are two items that must be analyzed. The first is that the core will remain subcritical. Second is that dose rates in and around the facility do not exceed 10 CFR 20 regulations. The focus of this work is to estimate the source term and the resulting dose rates at points external to the reactor building in the event of an uncovered core.

The OSTR SAR utilized the activity equation from LaMarsh [10], equation 7, to determine the activity present in the core as a function of time after shutdown. The limitations of this equation are that it only applies to one fuel pin, and it only takes into account one operating cycle. If the reactor has been cycled on and off, long lived fission product buildup may skew the source activity. In the analysis the source was modeled as a cylinder, and the total activity was divided by the volume of the cylinder to determine the source flux. The fission product activity and source strength as calculated in the SAR are shown in Table 1.

**Table 1. Fission Product Activity and Source Flux After Shutdown from the OSTR SAR.**

<b>Time After Shutdown</b>	<b>Fission Product Activity (Ci)</b>	<b>Flux/Core Height (<math>\mu\text{g}/\text{cm}^3\text{sec}</math>)</b>
10 seconds	8.15E+06	5.11E+12
1 hour	1.24E+06	7.78E+11
1 day	9.70E+05	6.08E+11
1 week	5.20E+05	3.26E+11
1 month	2.86E+05	1.79E+11

Once the source strength was determined, the dose rate at the reactor top was calculated using Equation 3:



$$\Phi = [S_v R^2 / 4\mu_c a^2] [1 - \exp(-\mu_c h)] \quad \text{Equation 3.}$$

where  $\Phi$  is  $\gamma \text{ cm}^{-2} \text{ sec}^{-1}$ ,  $S_v$  is the source flux per core height in  $\gamma \text{ cm}^{-3} \text{ sec}^{-1}$ ,  $R$  is the core radius in cm,  $\mu_c$  is the core attenuation coefficient ( $1/\text{cm}^{-1}$ ), and  $h$  is the core height. Once the photon flux was calculated in  $\gamma \text{ cm}^{-2} \text{ sec}^{-1}$ , a dose conversion factor of  $4.6 \times 10^{-12} \text{ Sv cm}^2 \gamma^{-1}$  was used to convert the flux to an effective dose equivalent rate. Table 2 shows the effective dose rates calculated in the OSTR SAR at the top of the cement bioshield. This methodology has also been used at other research reactor facilities [11].

**Table 2. Effective Dose Rates at Reactor Top after Shutdown from the OSTR SAR.**

Time After Shutdown	Effective Dose Equivalent Rate (rem/hr)
10 seconds	1.00E+04
1 hour	1.52E+03
1 day	1.19E+03
1 week	6.39E+02
1 month	3.51E+02

The following analysis will compare effective dose equivalent rates determined with MCNP5 analysis to the effective dose equivalent rates from the SAR.

An article by Patton H McGinley [12] examines dose rates calculated using equations from the National Council on Radiation Protection and Measurements (NCRP) Report # 51 [13]. The article compares photon and neutron measured dose rates at an 18 MeV medical accelerator with those calculated using equations from the NCRP Report #51. According to McGinley, the equations overestimate the photon dose rates up to approximately 10 meters. At distances greater than 10 meters, the calculated photon dose rates are underestimated. According to the data presented in the McGinley article, a correction factor would need to be determined for the facility before relying strictly on NCRP equations to determine dose rates external to the OSTR.

### 3. Background Theory

#### 3.1 Fission Theory

Fission events produce fission fragments, neutrons, gamma rays and neutrinos. The fission fragments are charged particles since the fission process removes some of the electrons from the outer shells. The charged particles interact quickly within their surroundings, ionizing the atoms of the medium and losing energy. The neutrons, gamma rays and neutrinos are neutral in charge but behave differently. Neutral particles will travel in a straight trajectory until they collide with another particle. At this point they either are scattered or absorbed [7].

Neutrons are born with a distribution of energies, with an average energy of approximately 2 MeV, and may be characterized by their kinetic energy value. Neutron energies can be classified into three different neutron energies: fast, epithermal and thermal. Other energy ranges are defined, but fit within these three categories. Fast neutrons have an energy range from 0.01 to 10 MeV and their distribution,  $\chi(E)$ , is represented by Equation 5 [7]:

$$\chi(E)=0.453\exp(-1.036E)\sinh((2.29E)^{1/2}) \quad \text{Equation 5.}$$


where E is the energy in eV. The epithermal neutron energy range is approximately 1 to 10 keV, whereas thermal neutrons have energies less than 1 eV. Thermal neutron energy distribution is ideally characterized by the Maxwell-Boltzmann equation:

$$M(E)=\frac{2*\pi*E^{1/2}}{(\pi kT)^{3/2}} \exp(-E/kT) \quad \text{Equation 6.}$$

where E is the energy in eV, T is the temperature in K, and k is the Boltzmann Constant of  $8.617 \times 10^{-5}$  eV/K [7]. The energy ranges presented here are not definite values and may vary depending upon the definition.


In the case of the TRIGA reactor at OSU, the neutrons produced are moderated by the uranium hydride fuel and the primary coolant. Thermalized neutrons that diffuse in the core or re-enter the core from the primary coolant may go on to produce fission within the fuel.

During fissioning, the target nucleus will split into two different nuclei. When a thermal neutron causes fission, there is a well defined difference between the masses of the two newly created nuclei. If the neutron energy is greater than a few eV, the nuclei may split where the mass is distributed more equally. Figure 2 below depicts the dip in the fission yield curve for thermal energies, and the flattening of the curve for higher energy neutrons.



**Figure 2. Uranium 235 Fission yield vs. mass number [14].**

Lower atomic number isotopes have a neutron to proton ratio of 1:1. As atomic number increases, the isotopes reach stability with a higher number of neutrons than protons. Shown in Figure 3, the fission fragments created from fission typically do not have a stable ratio of neutrons to protons; therefore they will decay to reach the line of stability.



**Figure 3. Fission fragment instability diagram [9].**

Each daughter product of the fission fragment decay has a different decay half life. Thus, the time required to reach stability is different for each isotope created through fission [7].


### 3.2 Fission Product Decay Activity

The activity in curies produced by the decay products may be calculated by the following:

$$A(t) = 1.4 \times 10^6 P [t^{-0.2} - (t+T)^{-0.2}] \quad \text{Equation 7.}$$

where P is the reactor thermal power (MW), t is the time after shutdown in days, and T is the operating time prior to shutdown [10].

The OSTR operates approximately 7 hours per weekday at 1 MW power. Plotting Equation 7 versus time with a 7 hour reactor operating time gives the decay shown in Figure 4.




**Figure 4. Fission product activity as a function of time after OSTR shutdown.**

Using equation 7 with a 7 hour operating time the activity of the OSTR core is calculated to be 1.79 MCi at end of bombardment (EOB). During shut down the fission products decay, but longer lived isotopes do not completely dissipate. The next operating cycle adds to the amount of longer half life isotopes produced. The decay activity resulting from these longer lived isotopes causes a shift in the plot to a higher activity value than one would see if a reactor was shut down after constant operation.

### 3.3 Electromagnetic Radiation

Photons are the quantum of energy which comprises electromagnetic radiation (EMR) [15]. Photons have no mass, no charge, and travel at the speed of light. EMR classification depends upon the wavelength and frequency of the wave generated. Figure 5 shows the range of EMR and classification as a function of wavelength.



**Figure 5. Electromagnetic energy spectrum.**

Photon energies are inversely proportional to their wavelength. The relationship between energy and wavelength is given by:

$$E=hc/\lambda \quad \text{Equation 8.}$$

where  $h$  is Planck's constant,  $c$  is the speed of light, and  $\lambda$  is the wavelength.

Photons interact with the medium by absorption and scatter. Once photons have traveled through a medium, scattering may result in photons of a different energy or a different angle than the original photon beam [15]. Photons may travel a long distance in a medium before interacting, so they are the primary concern for estimating dose from uncovering of the OSTR. Photon interaction mechanisms are discussed further in the next section.

### 3.4 Shielding and Photon Interactions

The water surrounding the OSTR reactor core provides shielding for the emitted radiation, cooling for the reactor core and neutron moderation. Radiation traveling through a medium undergoes either geometric or material attenuation. Geometric

attenuation occurs when a given number of particles disperse into a larger volume of medium. Material attenuation occurs when the photons are absorbed from the incident photon beam, or scatter in a direction away from that of the incident photon beam [15].

To accurately describe the total attenuation through a material, both material and geometric attenuation must be taken into account. Once the photons have been scattered, they will enter a detector at an angle different from the initial beam angle or be scattered away from a detector. Radiation flux decreases in a material exponentially according to Equation 9:

$$I(x)=I(0)Be^{-\mu x} \quad \text{Equation 9.}$$

where  $I$  is the flux,  $B$  is the buildup factor,  $\mu$  is the linear attenuation coefficient and  $x$  is the distance the photon travels through the medium. The buildup factor is a correction factor based on the thickness and energy of the photons interacting with in a material. The correction factor takes into account photons that are scattered back toward the detector but are not taken into account by use of the linear attenuation coefficient alone.

### 3.4.1 Photoelectric Effect

Photoelectric effect occurs when a photon transfers sufficient energy to an inner shell electron, thus ejecting the electron from the atom [15]. The kinetic energy of the electron is equal to the energy of the incident photon minus the electron binding energy:

$$T = E_{\gamma} - B_e \quad \text{Equation 10.}$$

where  $E_{\gamma}$  is the energy of the incident photon and  $B_e$  is the binding energy [16]. The probability of the photoelectric effect increases with increasing atomic number,  $Z$ , and with lower energy photons. Typically the photons that undergo this type of interaction are less than 0.5 MeV.

### 3.4.2 Pair Production

Pair production occurs when a photon traversing a high electromagnetic field is converted into an electron positron pair. The energy of the incident photon must exceed 1.022 MeV to provide the rest mass energy of the electron and positron. The kinetic energy divided between the remaining electron and positron pair is:

$$T_e + T_p = E_\gamma - 2mc^2 \quad \text{Equation 11.}$$

where  $2mc^2$  is 1.022 MeV [16]. The positron electron pair will create ionizations in the surrounding material along their path. The greater the initial energy, the more energy is transferred to the surrounding medium. As the positron slows down, it will become attracted to an electron and will annihilate, producing two 511 keV gamma rays. The resulting gamma rays will continue within the medium, in exactly opposite directions [15].

### 3.4.3 Compton Scattering

Photons traveling through a medium with loosely bound outer electrons may undergo Compton scattering. The probability of interaction decreases as the photon energy decreases, and increases as the atomic number increases. In Compton scattering, the incoming photon collides with an outer shell electron. The collision transfers part of the photon energy to the electron, and both particles subsequently scatter. The kinetic energy of the electron after collision is dependent upon the initial photon energy and the scatter angle, and is calculated by Equation 12:

$$KE_e = \frac{(h\nu)}{m_0c^2} \cdot \frac{h\nu(1-\cos\theta)}{[1+h\nu/m_0c^2(1-\cos\theta)]} \quad \text{Equation 12.}$$

The maximum kinetic energy occurs when the scattering angle is  $180^\circ$  [15].



### 3.4.4 Coherent Scattering

Coherent scattering occurs when the incident photon wavelength is much greater than the radius of the atom or molecules they strike. The result is that the emitted photon will continue to travel at the same energy as before the collision. Coherent scattering differs from the previously mentioned types of scattering in that it: 1) does not result in a different particle emitted from the atom and 2) results in retention of all energy by the incident photon.

### 3.5 Ionization Chambers

An ion chamber is a type of detector that depends upon interactions within a gas medium to create ion pairs. Ion pairs are created as the radiation interacts within the gas by depositing energy and ionizing the atoms. The minimum amount of energy required to remove an electron from its shell ranges from 10 to 25 eV depending on the type of gas; however, not all energy deposited by the radiation results in the removal of an electron from its shell.

There are several factors that can reduce the number of ion pairs formed within the gas, including recombination and electron attachment. Recombination occurs when positive and negative ions join together to create neutral atoms. Electron attachment effectively reduces the number of free electrons in the ion chamber. As the electrons diffuse through the gas, a high electron affinity gas may attract electrons to a neutral atom. The result is an increase in negative ions within the gas.

To overcome the overall reduction in ion pairs, an electric field is applied to the ion chamber. The field induces separation of the negatively and positively charged particles. The oppositely charged particles migrate to electrodes, creating a current in the detector. The magnitude of the current produced is proportional to the number of ion pairs that are formed from ionization of the gas.

To account for the average energy lost to events that do not result in ion pairs, W-values were created. The W-value is a correction factor that takes into account the

type of radiation and the chamber gas. Knowing the W-value for the specified ion chamber gas and type of radiation, the energy of incident radiation can be determined from the number of ion pairs formed [17].

### 3.6 Dose and Dose Equivalent

Absorbed dose is the amount of energy from ionizing radiation deposited in a given medium [15]. The units of absorbed dose are rad, or gray in SI units. The absorbed dose is converted to dose equivalent in units of rem, or sieverts in SI units, by a quality factor. The quality factor takes into account the effectiveness of the radiation as compared to a standard low LET radiation.

For this research, the exposure values measured at distances above the reactor core are a starting point to calculate the dose rate. The exposure can either be measured with a detector or estimated using analytical methods. Once the exposure is determined, it is converted to rad by Equation 13:

$$1 \text{ R} = 0.877 \text{ rad (in air)} = D \text{ (absorbed dose)} \quad \text{Equation 13.}$$

where R is the measured or calculated exposure. A rad is the equivalent to 100 ergs of energy absorbed in 1 gram of absorbing medium [15].

The amount of biological damage incurred from radiation depends upon the type of incident radiation. Radiation that has a high linear energy transfer (LET) will do more damage than radiation with a low LET. A high LET radiation will deposit more energy over a given linear amount of tissue than a low LET radiation. To account for the differences in energy transfer rates, the absorbed dose is multiplied by a weighting factor to determine the dose equivalent.

$$H = D * Q \quad \text{Equation 14.}$$

where H is the dose equivalent in rem, D is the absorbed dose in rad, and Q is the weighting factor.

To determine the dose rate over a specified amount of time, the activity from equation 7 is integrated to give

$$\int A(t)dt = P [ 1.75E+6 \times t^8 - 1.75E+6 \times (t + T)^{0.8} ] \quad \text{Equation 15.}$$

where  $t$  is the time of interest, and  $T$  is the reactor operating time prior to shutdown. The integrated activity is then taken and substituted into equation 18 to give an exposure rate in R/hr. The dose rate is then calculated using equation 13.

### 3.7 Skyshine

Skyshine occurs when radiation traveling in an upward direction is scattered off of atoms in the atmosphere and travel back toward the earth [18]. In the case of a TRIGA reactor, the core is shielded with sixteen feet of water which attenuates the majority of the radiation produced. However, a LOCA would change the attenuating medium from water to air, significantly reducing the magnitude of the attenuation coefficient. Thus photons traversing a given distance in air would undergo less attenuation than photons traversing the same distance in water.

### 3.8 MCNP5

MCNP5, Monte Carlo N-Particle, was used to simulate the photon flux from the core and energy deposition in volumes of interest. Monte Carlo methods were originally developed by scientists at Los Alamos National Laboratory during the 1940s [19]. Monte Carlo (MC) methods are mathematically rigorous, and were first made practical for predicting particle transport with the invention of the computer. Computers allowed the multitude of calculations required for MC simulations to be performed in a reasonable time frame. The first version of MCNP was written in 1963, called MCS<sup>18</sup>. Through the years the code was increased in complexity with added particle types and broadening energy value ranges. In the 1970s, eigenvalue algorithms were added to determine  $k_{\text{eff}}$ .

MCNP simulates particle histories individually from birth to death, terminating each particle upon absorption or exiting the geometry. MCNP allows the user to define the particle transported in a specified geometry. The particle will start in an identified source point, area or volume. The user assigns the particle a given weight and energy. The direction of travel is then randomly selected. To determine the distance a particle travels, the probability of interaction along a given length is calculated by:

$$p(\ell) = \int e^{-\Sigma_t} \Sigma_t d\ell \quad \text{Equation 16.}$$

where  $p(\ell)$  is the probability of interaction from  $\ell$  to  $\ell + d\ell$ , and  $\Sigma_t$  is the total cross section. The probability is equal to a random number from zero to 1,  $\xi$ . The distance to the next interaction is then given by:

$$\ell = -(1/\Sigma_t) * \ln(\xi) \quad \text{Equation 17.}$$


Once the particle interacts, the type of collision is identified. The type of interaction is also determined by random probability based on the absorption, scattering and total cross sections. After the current particle terminates, the next particle is started and a new history is tracked.

The geometry is composed of surfaces and cells, in which surfaces are combined to create cells. The cells are defined by space that has a positive or negative directional relationship to each surface. Once the geometry has been created, the outside universe must be defined as a void. A void is a cell or cells with no material or cross section defined. Once the particle enters the void, the particle is terminated.

## 4. Materials and Methods

### 4.1 Exposure Measurements

In order to estimate the activity of the core, exposure measurements were taken using a Technical Associates model CP-MU ion chamber at six different heights above the core [20]. The ion chamber position relative to the core is shown in Figure 6.



**Figure 6. Ion chamber placement above reactor core.**

During the measurements, the primary water surrounded the core as removing the water for testing is unfeasible. The results of the exposure measurements at various heights are given in Table 3 [20].

**Table 3. Measured exposure rates at points above the OSTR.**

Description	Measured Exposure [R/hr]
Top of core	$1000 \pm 100$
1 ft above core	$360 \pm 100$
2 ft above core	$72 \pm 10$
3 ft above core	$10 \pm 1$
4 ft above core	$2 \pm 0.1$
5 ft above core	$0.4 \pm 0.01$

As expected, the measurements show an exponential decrease with distance. To determine the error of each measurement, the minimum ascertainable readout from the ion chamber meter was determined. The range for minimum and maximum values


was then determined by adding and subtracting the minimum measurement reading from the measured value. The measured exposure values were taken in 1999 during a routine survey of the reactor. There was only one set of exposure values taken at the time. Taking measurements to repeat for statistical accuracy would induce error by the measurement technique since the same employee is no longer available to repeat the measurements exactly.

#### **4.2 TRIGA Reactor Modeling**


MCNP5 was used to create a simplified model of the OSTR. The model includes the basic geometries of the core, primary coolant, ion chambers, bioshield, surrounding room air, facility building and air above and lateral to the reactor building. A complete MCNP5 input deck is provided in Appendix A.

The core was modeled as a cylindrical volume surrounded by water, cement, and room air. The fine details of the core, such as individual fuel elements and control rods, were not included. The assumptions made for the geometry and source were reasonable since the purpose of the source modeling was to determine a photon distribution and source activity. The ion chamber was modeled as a small cylindrical volume placed at specific heights above the core.

The bioshield and structure support were modeled as three different layers. The bottom layer was modeled as a rectangular base, with a cylinder of core material and water directly in the center. The middle layer is a cylinder of water surrounded by a cylinder of cement. The third layer is similar to the bottom layer with a rectangular shape concrete slab and a cylindrical water center. Figures 7 and 8 are side and top views of the OSTR model.



**Figure 7. Side Vertical view of the OSTR model.**



**Figure 8. Top view of the OSTR model.**

The true octagon shapes of the base and top were modeled as rectangles for ease of modeling. The material thickness of the base, beyond a few inches, is not considered significant since the photons would be attenuated significantly prior to reaching the narrowest width of cement. Also, attenuation from the aluminum housing of the ion chamber was neglected.

#### 4.2.1 Material Specification

The four materials specified for the model of the OSTR and surroundings are given in Table 4.

**Table 4. Material compositions for MCNP5 model.**

Material Number	Material	Material Component	Atom Percent
1	Cement	Calcium	31.3%
		Oxygen	55.7%
		Silicon	10.1%
		Aluminum	2.2%
		Iron	.7%
2	Water	Hydrogen	66.7%
		Oxygen	33.3%
3	Air	Nitrogen	75%
		Oxygen	25%
4	Stainless Steel (304)	Iron	70%
		Carbon	8%
		Chromium	18%
		Manganese	1%
		Silicon	1%
		Phosphorus	1%
		Sulfur	1%

The air was modeled with nitrogen and oxygen because together they account for greater than 99% of the mass percent of air.

#### 4.2.2 Tally Specification

The tally type used in MCNP5 was a \*F8 tally. The F8 tally sums the number of interactions of a certain energy deposited in a cell. The "\*" modifier in front of the F8 changes the tally by tracking and summing the energy deposited per initiated particle in the volume of interest [19]. The \*F8 tally was chosen because absorbed dose can easily be calculated from the results which are given in units of MeV per initial photon.



Only photon energy deposition is considered important in this analysis. Once the LOCA occurs, the large negative temperature coefficient of the reactor fuel effectively shuts off the fission reactions within the core. Charged particle deposition is ignored since they interact with the surrounding atoms and come to rest after relatively short distances compared to the photons.

#### 4.2.3 Source Specification

Of particular importance is the energy distribution of the photons. The source was modeled as a photon emitting cylinder. Multiple simulations were run with varying initial photon energies for each simulation. The first six simulations were run with monoenergetic photons. The seventh simulation used a Maxwellian distribution and simulations 8 through 13 were run with a distribution of energies from 1 to 10 MeV. The distributions were based on percentages determined from the monoenergetic photon simulations. The distributions are described further in section 5.2. Table 5 lists the energy values used for each simulation.

**Table 5. Initial photon energy values for MCNP5 simulations.**

Simulation		Energy Values
<b>1</b>	Monoenergetic	1 MeV
<b>2</b>	Monoenergetic	2 MeV
<b>3</b>	Monoenergetic	3 MeV
<b>4</b>	Monoenergetic	5 MeV
<b>5</b>	Monoenergetic	7.5 MeV
<b>6</b>	Monoenergetic	10 MeV
<b>7</b>	Maxwellian	Maxwellian Distribution
<b>8</b>	Distribution 1	Distribution 1 to 10 MeV
<b>9</b>	Distribution 2	Distribution 1 to 10 MeV
<b>10</b>	Distribution 3	Distribution 1 to 10 MeV
<b>11</b>	Distribution 4	Distribution 1 to 10 MeV
<b>12</b>	Distribution 5	Distribution 1 to 10 MeV
<b>13</b>	Distribution 6	Distribution 1 to 10 MeV

## 5. Results

### 5.1 Exposure Rates – Monoenergetic Photons

MCNP5 simulations 1 through 6 were run using monoenergetic photon energies, with and without the primary water present. The source activity was calculated with water, based on the energy deposited in the cell positioned directly above the reactor core. The simulation including the primary water was used to determine the source activity because the exposure measurements were taken while the core was surrounded by primary coolant. The activity was then calculated by:

$$A = \frac{E}{[PE * J * 100 \text{ rad/Gy}] / [.877 \text{ rad/R} * M]} \quad \text{Equation 18.}$$

where A is the activity in photons per hour, E is the exposure in R per hour, PE is the \*F8 tally results in MeV per initial photon, J is a MeV to Joules conversion factor of  $1.6 \times 10^{-13}$ , M is the mass of each cell in kg.

The tally for the cell directly on the core top had the lowest error due to the largest number of particles deposited in the cell. After the core activity was determined using the energy deposited in the cell directly on top of the core, equation 18 was rearranged to solve for E of the remaining cells simulating the ion chamber. Tables 6 and 7 provide the source activity and calculated exposure rates in comparison to the measured exposure rates for simulations 1 through 6, with and without water. Figures 9 and 10 are graphs of exposure rates calculated from the monoenergetic photon energy simulations versus the measured exposure values. The measured values are the same in both graphs; however, the calculated values differ by simulation with or without primary water.

Table 6. Source activity and calculated exposure rates for monoenergetic photon energies in water.

		1 MeV		2 MeV		3 MeV	
Position	R/hr (Measured)	Source Activity (y/hr)	R/hr (Calculated)	Source Activity (y/hr)	R/hr (Calculated)	Source Activity (y/hr)	R/hr (Calculated)
Top of core	1000 ± 100	5.47E+17	1000 ± 0.30	3.49E+17	1000 ± 0.30	2.61E+17	1000 ± 0.30
1 ft above core	360 ± 100		37.9 ± 0.04		48.86 ± 0.054		55.6 ± 0.067
2 ft above core	72 ± 10		3.4 ± 0.01		6.67 ± 0.019		9.19 ± 0.26
3 ft above core	10 ± 1		0.34 ± 0.003		1.096 ± 0.0076		1.86 ± 0.011
4 ft above core	2 ± .1		0.053 ± 0.004		0.26 ± 0.0036		0.536 ± 0.006
5 ft above core	0.4 ± 0.01		0.006 ± 0.0004		0.05 ± 0.0016		0.132 ± 0.003
Reactor Top			0 ± 0.00		0.0 ± 0.0		0.00 ± 0.00
		5 MeV		7.5 MeV		10 MeV	
Position	R/hr (Measured)	Source Activity (y/hr)	R/hr (Calculated)	Source Activity (y/hr)	R/hr (Calculated)	Source Activity (y/hr)	R/hr (Calculated)
Top of core	1000 ± 100	1.82E+17	1000 ± 0.400	1.35E+17	1000 ± 0.4	1.08E+17	1000 ± 0.4
1 ft above core	360 ± 100		63.1 ± 0.082		67.7 ± 0.095		99.2 ± 0.14
2 ft above core	72 ± 10		12.4 ± 0.035		14.68 ± 0.04		15.9 ± 0.05
3 ft above core	10 ± 1		3.12 ± 0.017		4.16 ± 0.02		4.8 ± 0.024
4 ft above core	2 ± .1		1.08 ± 0.0096		1.6 ± 0.013		1.96 ± 0.15
5 ft above core	0.4 ± 0.01		0.337 ± 0.005		0.55 ± 0.007		0.72 ± 0.009
Reactor Top			0.00 ± 0.00		0.00 ± 0.00		0.00 ± 0.00




Figure 9. Exposure rates calculated from MCNP5 results in water.

Table 7. Source activity and calculated exposure rates for monoenergetic photon energies in air.

		1 MeV		2 MeV		3 MeV	
Position	R/hr (Measured)	Source Activity (γ/hr)	R/hr (Calculated)	Source Activity (γ/hr)	R/hr (Calculated)	Source Activity (γ/hr)	R/hr (Calculated)
Top of core	1000 ± 100	5.47E+17	1000 ± 7.00	3.24E+17	1000 ± 8.10	2.38E+17	1000 ± 8.8
1 ft above core	360 ± 100		112 ± 2.30		109 ± 2.65		104 ± 2.79
2 ft above core	72 ± 10		43.6 ± 1.44		44.1 ± 1.7		42.5 ± 1.81
3 ft above core	10 ± 1		22.6 ± 1.01		21.5 ± 1.16		20.1 ± 1.22
4 ft above core	2 ± .1		14.7 ± 0.81		14.2 ± 0.94		14.12 ± 1.02
5 ft above core	0.4 ± 0.01		10.2 ± 0.65		9.8 ± 0.77		9.54 ± 0.83
Reactor Top			0.84 ± 0.19		0.93 ± 0.23		0.60 ± 0.18
		5 MeV		7.5 MeV		10 MeV	
Position	R/hr (Measured)	Source Activity (γ/hr)	R/hr (Calculated)	Source Activity (γ/hr)	R/hr (Calculated)	Source Activity (γ/hr)	R/hr (Calculated)
Top of core	1000 ± 100	1.61E+17	1000 ± 9.6	1.12E+17	1000 ± 10.1	8.48E+16	1000 ± 10.3
1 ft above core	360 ± 100		105 ± 3.11		107 ± 3.3		367 ± 11.5
2 ft above core	72 ± 10		42 ± 1.96		41 ± 2.04		41.4 ± 2.08
3 ft above core	10 ± 1		19.5 ± 1.33		19.3 ± 1.38		19.2 ± 1.4
4 ft above core	2 ± .1		13.9 ± 1.12		13.9 ± 1.17		13.8 ± 1.19
5 ft above core	0.4 ± 0.01		10.1 ± 0.95		10.1 ± 1.01		9.9 ± 1.01
Reactor Top			0.58 ± 0.21		0.61 ± 0.22		0.56 ± 0.21




Figure 10. Exposure rates (R/h) at various heights above the TRIGA reactor core in air.

The exposure levels simulated in water did not exceed the measured values. However, the exposure levels in air exceeded measured values as the distance above the core increased. The larger energy deposition in air cells farther from the core occurred because the photons underwent fewer collisions in the air medium, thus retaining greater amounts of their initial energy at greater distances from the core.

The \*F8 tally results that would be required to equal the measured exposure values were back calculated using Equation 18. The energies per photon that would equate to the measured exposure values are displayed in Table 8.

**Table 8. \*F8 tally equivalent to the measured exposure values.**

	<b>*F8 Tally Equivalent [MeV/photon]</b>		
<b>Position</b>	<b>1 MeV</b>	<b>2 MeV</b>	<b>3 MeV</b>
<b>Top of Core</b>	3.9580E-05	6.6843E-05	9.0926E-05
<b>1 ft above</b>	1.4249E-05	2.4063E-05	3.2733E-05
<b>2 ft above</b>	2.8498E-06	4.8127E-06	6.5467E-06
<b>3 ft above</b>	3.9580E-07	6.6843E-07	9.0926E-07
<b>4 ft above</b>	7.9160E-08	1.3369E-07	1.8185E-07
<b>5 ft above</b>	1.5832E-08	2.6737E-08	3.6370E-08
<b>Reactor Top</b>	3.3158E-08	6.2386E-08	5.4795E-08
<b>Position</b>	<b>5 MeV</b>	<b>7.5 MeV</b>	<b>10 MeV</b>
<b>Top of Core</b>	1.3445E-04	1.9258E-04	2.5514E-04
<b>1 ft above</b>	4.8403E-05	6.9328E-05	9.1849E-05
<b>2 ft above</b>	9.6805E-06	1.3866E-05	1.8370E-05
<b>3 ft above</b>	1.3445E-06	1.9258E-06	2.5514E-06
<b>4 ft above</b>	2.6890E-07	3.8515E-07	5.1027E-07
<b>5 ft above</b>	5.3781E-08	7.7031E-08	1.0205E-07
<b>Reactor Top</b>	7.8605E-08	1.1826E-07	1.4299E-07

The \*F8 tally results equivalent to the measured exposure rates were then plotted with the MCNP5 simulated \*F8 tally results for each monoenergetic photon source. The plots are shown in Figures 11 through 16, below.




Figure 11. Energy deposited by 1 MeV photons in a simulated ion chamber as a function of distance from the core.




Figure 12. Energy deposited by 2 MeV photons in a simulated ion chamber as a function of distance from the core.






Figure 13. Energy deposited by 3 MeV photons in a simulated ion chamber as a function of distance from the core.




Figure 14. Energy deposited by 5 MeV photons in a simulated ion chamber as a function of distance from the core.




Figure 15. Energy deposited by 5 MeV photons in a simulated ion chamber as a function of distance from the core.




Figure 16. Energy deposited by 10 MeV photons in a simulated ion chamber as a function of distance from the core.

The height at which the plots intersect is approximately 2.7 ft above the core in each case. This height represents the average height required for the number of interactions simulated to be equivalent to the number of interactions equaling the measured exposure values. The number of interactions that occurred in each ion chamber cell was divided by the total number of initiated particles - 300,000,000 for each simulation. The particles interacting in the first, second and third cell, prior to the intersection point, were summed. The percentages of total particles interacting prior to the intersection point were ratioed to 100% and are listed in Table 9.

**Table 9. Percent of initial particles to interact prior to intersection point.**

MeV	% Particles Between 2' and 3'	% Particles to Reach Intersection	% Particles weighted to 100%
1	0.69	0.0112%	48.71%
2	0.71	0.0083%	36.32%
3	0.75	0.0015%	6.59%
5	0.76	0.0008%	3.64%
7.5	0.77	0.0007%	2.91%
10	0.77	0.0004%	1.83%

The monoenergetic photon energy simulations were only an energy estimation starting point, and it was understood that the photons produced from the core would have a distribution of energies. The percentages listed in Table 9 were determined to help define the photon source spectral shape.

## 5.2 Exposure Rates – Energy Distributions

The first simulation using an energy distribution, simulation 8, was run with source photon energy percentages as listed in Table 9. The measured exposure values and calculated exposure values of simulation 8 are presented in Table 10.

**Table 10. Source activity and calculated exposure of simulation 8.**

Position Above Core (ft)	Source Activity ( $\gamma$ /hr)	Calculated Exposure Rate (R/hr)	Measured Exposure Rate (R/hr)
0	4.3211E+16 $\pm$ 1.39E+15	1000 $\pm$ 100	1000 $\pm$ 100
1		180 $\pm$ 100	360 $\pm$ 100
2		47 $\pm$ 10	72 $\pm$ 10
3		10.8 $\pm$ 1	10 $\pm$ 1
4		1.46 $\pm$ 0.1	2 $\pm$ 0.1
5		0.46 $\pm$ 0.01	0.4 $\pm$ 0.01
16		0.00 $\pm$ 0.01	

A plot of the calculated versus measured exposure with corresponding errors is shown in Figure 17. The exposures rates in the ion chamber positions 3 ft and higher are within the error limits for the measured exposure. Simulations 9 through 11 were then run with varied percentages to attempt a closer match to the measure exposure values. However, simulation 8 most closely matched the measured exposure rates.




Figure 17. Exposure rates (R/hr) from simulation 8 and measured values at various heights above the TRIGA reactor core.


### 5.3 Dose Calculation at the Reactor Top

After approximating the photon energy distribution, MCNP5 was run with all primary water surrounding the core removed. Equation 18 was rearranged to solve for the dose rate at the reactor top using the \*F8 tally from the MCNP5. The activity was the source activity from simulation 8. The exposure rates as a function of height above the core 7 hours after shutdown are given in Table 11.

**Table 11. Simulated exposure levels for a LOCA at positions above the reactor core.**


Position	Source Activity (γ/Hour)	R/hr (Calculated)	MCNP Mev/Initial Photon
Top of core	4.3211E+16 ± 1.39E+15	2212 ± 53	1.1078E-05 ± 2.669798E-07
1 ft above core		839 ± 31	4.2002E-06 ± 1.558270E-07
2 ft above core		429 ± 23	2.1492E-06 ± 1.126165E-07
3 ft above core		276 ± 18	1.3812E-06 ± 9.184914E-08
4 ft above core		187 ± 14	9.3516E-07 ± 7.023029E-08
5 ft above core		159 ± 14	7.9514E-07 ± 7.124472E-08
Reactor Top		10 ± 2	5.0351E-08 ± 1.194319E-08

The source activity was then converted to curies and compared to the activity calculated with Equation 7. A plot of the activity versus time is shown in Figure 18. The individual data point is the activity at the reactor top determined from MCNP5 7 hours after shutdown. The time gap of 7 hours was used because the initial exposure measurements were taken 7 hours after the reactor was shutdown. The exposure measurements were taken prior to the beginning of this project, and the gap of 7 hours was outside of the scope of control for this project.



**Figure 18. Fission product activity as a function of time after shutdown with activity calculated using Equation 7.**

The activity estimated from MCNP5 is less than the activity estimated from core exposure measurements and equation 7. The MCNP5 model significantly underestimates source activity because it only accounted for decays which emitted photons but not other types of emitted radiation. The reactor operating time in equation 7 was adjusted to account for the discrepancy, effectively shifting the curve in Figure 18 so that the individual data point of activity lies on the curve.



**Figure 19. Corrected fission product activity.**

At time zero, the activity of the core was estimated at  $3.79 \times 10^4$  Ci, or  $5.05 \times 10^{18}$  photons per hour. Using this activity, exposure rates were calculated at times after shutdown, and are displayed in Table 12. .

The differences in the activity determined from MCNP5 versus the activity using equation 7 are due to several assumptions used for the equation. First, the MCNP5 model assumes the only radiation energy depositing in the cells is from photons. Equation 7 takes into account radioactive decay produced from all radiation; therefore decays that result in alpha and neutron radiation would be absent from the MCNP5 model. MCNP5 does track the electrons created during the photon interactions and, for the photon only mode, deposits their energy at the point of the photon interaction. Secondly, the TRIGA reactor operation is cyclic with start ups and shutdowns throughout the year on an almost daily basis. The cyclic operation will result in a buildup of longer lived isotopes over a period of time, while



allowing time for the shorter lived isotopes to decay away. This cyclic operation is not accounted for in equation 7.

Using activity values from Figure 19, the exposure was calculated for various times after shutdown. Using equation 13, exposure rate was converted to dose rate and a weighting factor of 1 for photons was used to convert dose rate to dose equivalent rate. The results are compared with the OSTR SAR predicted dose equivalent rates in Table 12.

**Table 12. Exposure and dose rates after LOCA at the top of the TRIGA® bioshield.**

Time	Source Activity (γ/Hour)	Exposure Rate (R/hr)	Dose Rate (rad/hr)	Dose Equivalent Rate (rem/hr)	Dose Equivalent Rate from SAR (rem/hr)
<b>0</b>	5.055E+18	1031	904	904	1.00E+04
<b>1 hr</b>	4.041E+17	82	72	72	1.52E+03
<b>1 day</b>	8.947E+15	2	2	2	1.19E+03
<b>1 week</b>	8.662E+14	0.18	0.2	0.2	6.39E+02
<b>1 month</b>	1.511E+14	0.03	0.03	0.03	3.51E+02

#### 5.4 Facility External Dose

Dose rates external to the reactor building are given in Figure 20. The figure displays the maximum dose rate, for each 1 meter width increment, on the east side of the reactor building. The range of interest extends from the OSTR east wall up to 60 meters in the horizontal direction. The horizontal blocks, shown in Figure 21, demonstrate an aerial view of the 5 rows of cells that of were modeled from 0 to 100 cm in the z-axis direction (height) east of the reactor facility. Each block contained 60 of the 1 meter in width and height cells.





Figure 20. Dose rates external to OSTR from 0 to 100 cm in height.



**Figure 21. Cell positions for photon dose rates in Figure 19.**

Dose rates on the OSTR exterior peak at approximately 30 mrem/hr. The dose rates calculated assume an activity equivalent to the activity present exactly at the end of bombardment.

To determine the dose received within the first hour after a LOCA event, equation 7 was integrated from time 0 hr to time 1 hr after shutdown. The operating time used was 0.00239923 days, which corresponds to the operating time required to match the MCNP5 modeled core activity. The dose within the first hour is  $5.33\text{E-}3$  mrem using the integrated activity from equation 15.

## 6 Conclusion

This thesis presented an approach to estimate dose rates due to photon skyshine on the exterior of the OSTR building in the event of a LOCA. The findings presented herein indicate that the dose rates of a cell 1 meter in

height may meet the NRC limit of 2 mrem/hr in the event of a LOCA at the OSTR. The dose rates at the reactor top were estimated to be less than the values calculated in the OSTR SAR. However, a direct comparison for the skyshine is not available from the OSTR SAR. The OSTR SAR only takes into account scatter from the reactor building ceiling, and not scatter due to skyshine from the atmosphere above the reactor building. However, the source strength initially used for dose rate calculations would be the same, so one may assume that an overestimation of dose rates at the facility perimeter would also occur.

There are two reasons why the results presented here do not match the OSTR SAR. First, the OSTR SAR assumes that the reactor has been operating continuously for the previous 365 days. This assumption will cause a higher value to be calculated for the activity using equation 7. In reality the reactor operates on a cyclic schedule, and the short lived isotopes have time to decay prior to the next start up. This reduction in short lived isotopes would reduce the activity estimated at shut down, which is consistent with the results obtained from this analysis. Secondly, the SAR assumes only monoenergetic photons of 1 MeV from the source. This is most likely an inaccurate assumption and affects the energy distribution seen at heights above the core.

## **6.1 Future Work**

The analysis presented for this thesis provides validation that the equations used in the OSTR SAR may be overestimating dose rates external to the radiation facility. Future work could involve the determination of a correction factor to be used in conjunction with the methods displayed in the OSTR SAR. A correction factor would provide less conservative, yet likely more accurate dose rates.

## BIBLIOGRAPHY

- [1] "Subpart D--Radiation Dose Limits for Individual Members of the Public". Nuclear Regulator Commission. 4/26/2010  
<<http://www.nrc.gov/reading-rm/doc-collections/cfr/part020/part020-1301.html>>.
- [2] U.S. Department of Energy, "The Manhattan Project". Office of History & Heritage Resources.5/7/2009  
<[http://www.cfo.doe.gov/me70/manhattan/cp-1\\_critical.htm](http://www.cfo.doe.gov/me70/manhattan/cp-1_critical.htm)>.
- [3] Teller, Edward, and Judith Schoolery. Memoirs: A Twentieth-Century Journey in Science and Politics. Cambridge: Perseus Books Group, 2001.
- [4] General Atomics. "TRIGA Research Reactors". General Atomics. 4/15/2010 <<http://www.gaes.com/triga/about/index.php>>.
- [5] Radiation Center: Irradiation Facilities". Oregon State University. 2/15/2010 <<http://radiationcenter.oregonstate.edu/Irrad%20Facilities/Facilities%20home.html>>.
- [6] Anderson, T.V., *Oregon State TRIGA Reactor Training Manual*. 1990.
- [7] Lewis, Elmer E.. Fundamentals of Nuclear Reactor Physics. San Diego: Elsevier Inc., 2008.
- [8] "Appendix A to Part 50--General Design Criteria for Nuclear Power Plants". Nuclear Regulator Commission. 4/26/2010  
<<http://www.nrc.gov/reading-rm/doc-collections/cfr/part050/part050-appa.html>>.
- [9] *Safety Analysis Report for the Oregon State University TRIGA Reactor*. Rev. 0, 2004. Print
- [10] Lamarsh, John R. Introduction to Nuclear Engineering, 3rd Edition . New Jersey: Prentice Hall, 2001.
- [11] *Safety Analysis Report for the UC Davis TRIGA Reactor*. Print.

- [12] McGinley, Patton H. "Radiation Skyshine Produced by an 18 MeV Medical Accelerator." *Radiation Protection Management*, Vol 10 No. 5, 1993. pp. 59-64.
- [13] National Council on Radiation Protection and Measurements, Radiation protection design guidelines for 0.1-100 MeV particle accelerator facilities. Washington, D.C.: NCRP; NCRP Report No. 51; 1977.
- [14] US Department of Energy, DOE FUNDAMENTALS HANDBOOK NUCLEAR PHYSICS AND REACTOR THEORY. 2 vols. Washington D.C.: Department of Energy, 1993.
- [15] Martin, James E. Physics for Radiation Protection, a Handbook, 2<sup>nd</sup> ed. Germany: Wiley-VCH, 2006.
- [16] Lilley, John. Nuclear Physics: Principles and Applications. Hoboken: John Wiley & Sons, Inc., 2001.
- [17] Knoll, Glenn F. Radiation Detection and Measurement, 3<sup>rd</sup> ed. Hoboken: Wiley, 2000.
- [18] Lagunita, I.S., et al.. "Skyshine from photon radiation". Atomic Energy February, 1989: 118-124.
- [19] X-5 Monte Carlo Team, MCNP - A General Monte Carlo N-Particle Transport Code, Version 5. 3 vols. Los Alamos , 2003.
- [20] *Non-Routine (Special) Radiation Survey Record*. Corvallis, Oregon: Oregon State University Radiation Center, 1999. Print.

## APPENDICES

## A APPENDIX – MCNP5 INPUT FOR LOCA SIMULATION

### TRIGA REACTOR

#### c cell definitions

1 1 -3.12 1 -2 3 -4 5 -6 13 \$Bioshield Base  
 2 3 -.0012 6 -2 3 -4 5 -12 13 \$Second Layer Bioshield  
 3 1 -3.12 12 -11 -2 3 -4 5 13 \$Third Layer Bioshield  
 4 3 -.0012 1 -11 22 4 -28 -24 \$Room Air North  
 5 3 -.0012 1 -11 26 -5 22 -24 \$Room Air South  
 6 3 -.0012 1 -11 -24 2 -4 5 \$Room Air East  
 7 3 -.0012 1 -11 -14 22 -4 5 \$Room Air West (West PIF)  
 8 3 -.0012 1 -33 -4 17 -3 14 \$Room Air West (North PIF)  
 9 3 -.0012 1 -33 -19 5 -3 14 \$Room Air West (South PIF)  
 10 3 -.0012 -11 33 14 -3 -4 5 \$Room Air West (Top PIF)  
 11 3 -.0012 11 -30 3 -2 -28 26 \$Room Air Top - Middle  
 12 3 -.0012 11 -30 -3 22 -28 26 \$Room Air Top - West  
 13 3 -.0012 11 -30 2 -24 -28 26 \$Room Air Top - East  
 14 1 -3.12 1 -30 24 -25 26 -28 \$East Wall  
 15 1 -3.12 1 -30 -22 23 26 -28 \$West Wall  
 16 1 -3.12 1 -30 -29 28 23 -25 \$North Wall  
 17 1 -3.12 1 -30 -26 27 23 -25 \$South Wall  
 18 4 -8.0 30 -31 23 -25 -29 27 \$Ceiling  
 c 19 0 -1:31:-23:25:-27:29 \$Void  
 20 1 -3.12 1 -11 -13 32 \$Cylinder Cement  
 c 21 0 1 -32 -11 \$Cylinder Void  
 22 1 -3.12 1 -33 14 -21 -17 19 \$West Wall - PIF  
 23 1 -3.12 1 -33 -17 18 21 -16 \$North Wall - PIF  
 24 1 -3.12 1 -33 -17 19 -3 16 \$East Wall - PIF  
 25 1 -3.12 1 -33 -20 19 -16 21 \$South wall - PIF  
 26 2 -1 1 -33 -18 20 -16 21 \$PIF Water  
 27 3 -.0012 1 -31 -36 37 -34 78 \$North Field Outside Reactor  
 28 3 -.0012 1 -31 -36 37 -67 35 \$South Field Outside Reactor  
 c 29 3 -.0012 1 -31 -29 27 -36 134 \$East Field Outside Reactor  
 30 3 -.0012 1 -31 -29 27 -55 37 \$West Field Outside Reactor  
 c 31 3 -.0012 31 -38 -34 35 -36 37 \$Air Above Reactor Building  
 32 0 -1:38:34:-35:36:-37 \$Void outside of Fields  
 33 3 -.0012 1 -11 -32 39 \$Water outside of core cylinder volume (lateral only)  
 34 3 -.0012 1 -40 -39 \$Outside portion of core cylinder (water below core)  
 35 2 -1 40 -41 -39 \$Outside portion of core cylinder (core material)  
 36 3 -.0012 41 -52 53 -39 \$Water above core, outside test air cylinders (Water, Bottom)  
 c 37 2 -1 1 -40 -53 \$Inside portion of core cylinder (water below core)  
 c 38 2 -19.05 40 -41 -53 \$Inside portion of core cylinder (Core Material)  
 39 3 -.0012 41 -42 -53 \$Inside portion of core cylinder - Air TEST 1  
 40 3 -.0012 42 -43 -53 \$Inside portion of core cylinder - Water 1'  
 41 3 -.0012 43 -44 -53 \$Inside portion of core cylinder - Air TEST 2  
 42 3 -.0012 44 -45 -53 \$Inside portion of core cylinder - Water 2'  
 43 3 -.0012 45 -46 -53 \$Inside portion of core cylinder - Air TEST 3  
 44 3 -.0012 46 -47 -53 \$Inside portion of core cylinder - Water 3'  
 45 3 -.0012 47 -48 -53 \$Inside portion of core cylinder - Air TEST 4  
 46 3 -.0012 48 -49 -53 \$Inside portion of core cylinder - Water 4'  
 47 3 -.0012 49 -50 -53 \$Inside portion of core cylinder - Air TEST 5  
 48 3 -.0012 50 -51 -53 \$Inside portion of core cylinder - Water 5'  
 49 3 -.0012 51 -52 -53 \$Inside portion of core cylinder - Air Test 6  
 50 3 -.0012 52 -54 -53 \$Inside portion of core cylinder - Water 6'  
 51 3 -.0012 52 -11 53 -39 \$ Water Above core, outside test air cylinders (Top)  
 52 3 -.0012 54 -11 -53 \$Top most air test cylinder  
 c cells external to facility for dose calculations  
 53 3 -.0012 1 -31 55 -56 67 -68  
 54 3 -.0012 1 -31 56 -57 67 -68  
 55 3 -.0012 1 -31 57 -58 67 -68  
 56 3 -.0012 1 -31 58 -23 67 -68



57 3 -.0012 1 -31 23 -59 67 -68  
58 3 -.0012 1 -31 59 -60 67 -68  
59 3 -.0012 1 -31 60 -61 67 -68  
60 3 -.0012 1 -31 61 -62 67 -68  
61 3 -.0012 1 -31 62 -25 67 -68  
62 3 -.0012 1 -31 25 -63 67 -68  
63 3 -.0012 1 -31 63 -64 67 -68  
64 3 -.0012 1 -31 64 -65 67 -68  
65 3 -.0012 1 -31 65 -66 67 -68  
66 3 -.0012 1 -31 55 -56 68 -69  
67 3 -.0012 1 -31 56 -57 68 -69  
68 3 -.0012 1 -31 57 -58 68 -69  
69 3 -.0012 1 -31 58 -23 68 -69  
70 3 -.0012 1 -31 23 -59 68 -69  
71 3 -.0012 1 -31 59 -60 68 -69  
72 3 -.0012 1 -31 60 -61 68 -69  
73 3 -.0012 1 -31 61 -62 68 -69  
74 3 -.0012 1 -31 62 -25 68 -69  
75 3 -.0012 1 -31 25 -63 68 -69  
76 3 -.0012 1 -31 63 -64 68 -69  
77 3 -.0012 1 -31 64 -65 68 -69  
78 3 -.0012 1 -31 65 -66 68 -69  
79 3 -.0012 1 -31 55 -56 69 -70  
80 3 -.0012 1 -31 56 -57 69 -70  
81 3 -.0012 1 -31 57 -58 69 -70  
82 3 -.0012 1 -31 58 -23 69 -70  
83 3 -.0012 1 -31 23 -59 69 -70  
84 3 -.0012 1 -31 59 -60 69 -70  
85 3 -.0012 1 -31 60 -61 69 -70  
86 3 -.0012 1 -31 61 -62 69 -70  
87 3 -.0012 1 -31 62 -25 69 -70  
88 3 -.0012 1 -31 25 -63 69 -70  
89 3 -.0012 1 -31 63 -64 69 -70  
90 3 -.0012 1 -31 64 -65 69 -70  
91 3 -.0012 1 -31 65 -66 69 -70  
92 3 -.0012 1 -31 55 -56 70 -27  
93 3 -.0012 1 -31 56 -57 70 -27  
94 3 -.0012 1 -31 57 -58 70 -27  
95 3 -.0012 1 -31 58 -23 70 -27  
96 3 -.0012 1 -31 23 -59 70 -27  
97 3 -.0012 1 -31 59 -60 70 -27  
98 3 -.0012 1 -31 60 -61 70 -27  
99 3 -.0012 1 -31 61 -62 70 -27  
100 3 -.0012 1 -31 62 -25 70 -27  
101 3 -.0012 1 -31 25 -63 70 -27  
102 3 -.0012 1 -31 63 -64 70 -27  
103 3 -.0012 1 -31 64 -65 70 -27  
104 3 -.0012 1 -31 65 -66 70 -27  
105 3 -.0012 1 -31 55 -56 27 -71  
106 3 -.0012 1 -31 56 -57 27 -71  
107 3 -.0012 1 -31 57 -58 27 -71  
108 3 -.0012 1 -31 58 -23 27 -71  
109 3 -.0012 1 -31 55 -56 71 -72  
110 3 -.0012 1 -31 56 -57 71 -72  
111 3 -.0012 1 -31 57 -58 71 -72  
112 3 -.0012 1 -31 58 -23 71 -72  
113 3 -.0012 1 -31 55 -56 72 -73  
114 3 -.0012 1 -31 56 -57 72 -73  
115 3 -.0012 1 -31 57 -58 72 -73  
116 3 -.0012 1 -31 58 -23 72 -73  
117 3 -.0012 1 -31 55 -56 73 -74

118 3 -.0012 1 -31 56 -57 73 -74  
119 3 -.0012 1 -31 57 -58 73 -74  
120 3 -.0012 1 -31 58 -23 73 -74  
121 3 -.0012 1 -31 55 -56 74 -29  
122 3 -.0012 1 -31 56 -57 74 -29  
123 3 -.0012 1 -31 57 -58 74 -29  
124 3 -.0012 1 -31 58 -23 74 -29  
c 125 3 -.0012 1 -31 25 -63 27 -71  
c 126 3 -.0012 1 -31 63 -64 27 -71  
c 127 3 -.0012 1 -31 64 -65 27 -71  
c 128 3 -.0012 1 -31 65 -66 27 -71  
c 129 3 -.0012 1 -31 25 -63 71 -72  
c 130 3 -.0012 1 -31 63 -64 71 -72  
c 131 3 -.0012 1 -31 64 -65 71 -72  
c 132 3 -.0012 1 -31 65 -66 71 -72  
c 133 3 -.0012 1 -31 25 -63 72 -73  
c 134 3 -.0012 1 -31 63 -64 72 -73  
c 135 3 -.0012 1 -31 64 -65 72 -73  
c 136 3 -.0012 1 -31 65 -66 72 -73  
c 137 3 -.0012 1 -31 25 -63 73 -74  
c 138 3 -.0012 1 -31 63 -64 73 -74  
c 139 3 -.0012 1 -31 64 -65 73 -74  
c 140 3 -.0012 1 -31 65 -66 73 -74  
c 141 3 -.0012 1 -31 25 -63 74 -29  
c 142 3 -.0012 1 -31 63 -64 74 -29  
c 143 3 -.0012 1 -31 64 -65 74 -29  
c 144 3 -.0012 1 -31 65 -66 74 -29  
145 3 -.0012 1 -31 55 -56 29 -75  
146 3 -.0012 1 -31 56 -57 29 -75  
147 3 -.0012 1 -31 57 -58 29 -75  
148 3 -.0012 1 -31 58 -23 29 -75  
149 3 -.0012 1 -31 23 -59 29 -75  
150 3 -.0012 1 -31 59 -60 29 -75  
151 3 -.0012 1 -31 60 -61 29 -75  
152 3 -.0012 1 -31 61 -62 29 -75  
153 3 -.0012 1 -31 62 -25 29 -75  
154 3 -.0012 1 -31 25 -63 29 -75  
155 3 -.0012 1 -31 63 -64 29 -75  
156 3 -.0012 1 -31 64 -65 29 -75  
157 3 -.0012 1 -31 65 -66 29 -75  
158 3 -.0012 1 -31 55 -56 75 -76  
159 3 -.0012 1 -31 56 -57 75 -76  
160 3 -.0012 1 -31 57 -58 75 -76  
161 3 -.0012 1 -31 58 -23 75 -76  
162 3 -.0012 1 -31 23 -59 75 -76  
163 3 -.0012 1 -31 59 -60 75 -76  
164 3 -.0012 1 -31 60 -61 75 -76  
165 3 -.0012 1 -31 61 -62 75 -76  
166 3 -.0012 1 -31 62 -25 75 -76  
167 3 -.0012 1 -31 25 -63 75 -76  
168 3 -.0012 1 -31 63 -64 75 -76  
169 3 -.0012 1 -31 64 -65 75 -76  
170 3 -.0012 1 -31 65 -66 75 -76  
171 3 -.0012 1 -31 55 -56 76 -77  
172 3 -.0012 1 -31 56 -57 76 -77  
173 3 -.0012 1 -31 57 -58 76 -77  
174 3 -.0012 1 -31 58 -23 76 -77  
175 3 -.0012 1 -31 23 -59 76 -77  
176 3 -.0012 1 -31 59 -60 76 -77  
177 3 -.0012 1 -31 60 -61 76 -77  
178 3 -.0012 1 -31 61 -62 76 -77

179 3 -.0012 1 -31 62 -25 76 -77  
180 3 -.0012 1 -31 25 -63 76 -77  
181 3 -.0012 1 -31 63 -64 76 -77  
182 3 -.0012 1 -31 64 -65 76 -77  
183 3 -.0012 1 -31 65 -66 76 -77  
184 3 -.0012 1 -31 55 -56 77 -78  
185 3 -.0012 1 -31 56 -57 77 -78  
186 3 -.0012 1 -31 57 -58 77 -78  
187 3 -.0012 1 -31 58 -23 77 -78  
188 3 -.0012 1 -31 23 -59 77 -78  
189 3 -.0012 1 -31 59 -60 77 -78  
190 3 -.0012 1 -31 60 -61 77 -78  
191 3 -.0012 1 -31 61 -62 77 -78  
192 3 -.0012 1 -31 62 -25 77 -78  
193 3 -.0012 1 -31 25 -63 77 -78  
194 3 -.0012 1 -31 63 -64 77 -78  
195 3 -.0012 1 -31 64 -65 77 -78  
196 3 -.0012 1 -31 65 -66 77 -78  
197 3 -.0012 1 -31 37 -55 29 -78  
198 3 -.0012 1 -31 66 -36 29 -78  
199 3 -.0012 1 -31 37 -55 67 -27  
200 3 -.0012 1 -31 66 -36 67 -27  
201 3 -0.0012 1 -98 25 -79 27 -71  
202 3 -0.0012 98 -31 25 -79 27 -71  
203 3 -0.0012 1 -98 25 -79 71 -72  
204 3 -0.0012 98 -31 25 -79 71 -72  
205 3 -0.0012 1 -98 25 -79 72 -73  
206 3 -0.0012 98 -31 25 -79 72 -73  
207 3 -0.0012 1 -98 25 -79 73 -74  
208 3 -0.0012 98 -31 25 -79 73 -74  
209 3 -0.0012 1 -98 25 -79 74 -29  
210 3 -0.0012 98 -31 25 -79 74 -29  
211 3 -0.0012 1 -98 79 -80 27 -71  
212 3 -0.0012 98 -31 79 -80 27 -71  
213 3 -0.0012 1 -98 79 -80 71 -72  
214 3 -0.0012 98 -31 79 -80 71 -72  
215 3 -0.0012 1 -98 79 -80 72 -73  
216 3 -0.0012 98 -31 79 -80 72 -73  
217 3 -0.0012 1 -98 79 -80 73 -74  
218 3 -0.0012 98 -31 79 -80 73 -74  
219 3 -0.0012 1 -98 79 -80 74 -29  
220 3 -0.0012 98 -31 79 -80 74 -29  
221 3 -0.0012 1 -98 80 -63 27 -71  
222 3 -0.0012 98 -31 80 -63 27 -71  
223 3 -0.0012 1 -98 80 -63 71 -72  
224 3 -0.0012 98 -31 80 -63 71 -72  
225 3 -0.0012 1 -98 80 -63 72 -73  
226 3 -0.0012 98 -31 80 -63 72 -73  
227 3 -0.0012 1 -98 80 -63 73 -74  
228 3 -0.0012 98 -31 80 -63 73 -74  
229 3 -0.0012 1 -98 80 -63 74 -29  
230 3 -0.0012 98 -31 80 -63 74 -29  
231 3 -0.0012 1 -98 63 -81 27 -71  
232 3 -0.0012 98 -31 63 -81 27 -71  
233 3 -0.0012 1 -98 63 -81 71 -72  
234 3 -0.0012 98 -31 63 -81 71 -72  
235 3 -0.0012 1 -98 63 -81 72 -73  
236 3 -0.0012 98 -31 63 -81 72 -73  
237 3 -0.0012 1 -98 63 -81 73 -74  
238 3 -0.0012 98 -31 63 -81 73 -74  
239 3 -0.0012 1 -98 63 -81 74 -29

240 3 -0.0012 98 -31 63 -81 74 -29  
241 3 -0.0012 1 -98 81 -82 27 -71  
242 3 -0.0012 98 -31 81 -82 27 -71  
243 3 -0.0012 1 -98 81 -82 71 -72  
244 3 -0.0012 98 -31 81 -82 71 -72  
245 3 -0.0012 1 -98 81 -82 72 -73  
246 3 -0.0012 98 -31 81 -82 72 -73  
247 3 -0.0012 1 -98 81 -82 73 -74  
248 3 -0.0012 98 -31 81 -82 73 -74  
249 3 -0.0012 1 -98 81 -82 74 -29  
250 3 -0.0012 98 -31 81 -82 74 -29  
251 3 -0.0012 1 -98 82 -64 27 -71  
252 3 -0.0012 98 -31 82 -64 27 -71  
253 3 -0.0012 1 -98 82 -64 71 -72  
254 3 -0.0012 98 -31 82 -64 71 -72  
255 3 -0.0012 1 -98 82 -64 72 -73  
256 3 -0.0012 98 -31 82 -64 72 -73  
257 3 -0.0012 1 -98 82 -64 73 -74  
258 3 -0.0012 98 -31 82 -64 73 -74  
259 3 -0.0012 1 -98 82 -64 74 -29  
260 3 -0.0012 98 -31 82 -64 74 -29  
261 3 -0.0012 1 -98 64 -83 27 -71  
262 3 -0.0012 98 -31 64 -83 27 -71  
263 3 -0.0012 1 -98 64 -83 71 -72  
264 3 -0.0012 98 -31 64 -83 71 -72  
265 3 -0.0012 1 -98 64 -83 72 -73  
266 3 -0.0012 98 -31 64 -83 72 -73  
267 3 -0.0012 1 -98 64 -83 73 -74  
268 3 -0.0012 98 -31 64 -83 73 -74  
269 3 -0.0012 1 -98 64 -83 74 -29  
270 3 -0.0012 98 -31 64 -83 74 -29  
271 3 -0.0012 1 -98 83 -84 27 -71  
272 3 -0.0012 98 -31 83 -84 27 -71  
273 3 -0.0012 1 -98 83 -84 71 -72  
274 3 -0.0012 98 -31 83 -84 71 -72  
275 3 -0.0012 1 -98 83 -84 72 -73  
276 3 -0.0012 98 -31 83 -84 72 -73  
277 3 -0.0012 1 -98 83 -84 73 -74  
278 3 -0.0012 98 -31 83 -84 73 -74  
279 3 -0.0012 1 -98 83 -84 74 -29  
280 3 -0.0012 98 -31 83 -84 74 -29  
281 3 -0.0012 1 -98 84 -65 27 -71  
282 3 -0.0012 98 -31 84 -65 27 -71  
283 3 -0.0012 1 -98 84 -65 71 -72  
284 3 -0.0012 98 -31 84 -65 71 -72  
285 3 -0.0012 1 -98 84 -65 72 -73  
286 3 -0.0012 98 -31 84 -65 72 -73  
287 3 -0.0012 1 -98 84 -65 73 -74  
288 3 -0.0012 98 -31 84 -65 73 -74  
289 3 -0.0012 1 -98 84 -65 74 -29  
290 3 -0.0012 98 -31 84 -65 74 -29  
291 3 -0.0012 1 -98 65 -85 27 -71  
292 3 -0.0012 98 -31 65 -85 27 -71  
293 3 -0.0012 1 -98 65 -85 71 -72  
294 3 -0.0012 98 -31 65 -85 71 -72  
295 3 -0.0012 1 -98 65 -85 72 -73  
296 3 -0.0012 98 -31 65 -85 72 -73  
297 3 -0.0012 1 -98 65 -85 73 -74  
298 3 -0.0012 98 -31 65 -85 73 -74  
299 3 -0.0012 1 -98 65 -85 74 -29  
300 3 -0.0012 98 -31 65 -85 74 -29

301 3 -0.0012 1 -98 85 -86 27 -71  
302 3 -0.0012 98 -31 85 -86 27 -71  
303 3 -0.0012 1 -98 85 -86 71 -72  
304 3 -0.0012 98 -31 85 -86 71 -72  
305 3 -0.0012 1 -98 85 -86 72 -73  
306 3 -0.0012 98 -31 85 -86 72 -73  
307 3 -0.0012 1 -98 85 -86 73 -74  
308 3 -0.0012 98 -31 85 -86 73 -74  
309 3 -0.0012 1 -98 85 -86 74 -29  
310 3 -0.0012 98 -31 85 -86 74 -29  
311 3 -0.0012 1 -98 86 -66 27 -71  
312 3 -0.0012 98 -31 86 -66 27 -71  
313 3 -0.0012 1 -98 86 -66 71 -72  
314 3 -0.0012 98 -31 86 -66 71 -72  
315 3 -0.0012 1 -98 86 -66 72 -73  
316 3 -0.0012 98 -31 86 -66 72 -73  
317 3 -0.0012 1 -98 86 -66 73 -74  
318 3 -0.0012 98 -31 86 -66 73 -74  
319 3 -0.0012 1 -98 86 -66 74 -29  
320 3 -0.0012 98 -31 86 -66 74 -29  
321 3 -0.0012 1 -98 66 -87 27 -71  
322 3 -0.0012 98 -31 66 -87 27 -71  
323 3 -0.0012 1 -98 66 -87 71 -72  
324 3 -0.0012 98 -31 66 -87 71 -72  
325 3 -0.0012 1 -98 66 -87 72 -73  
326 3 -0.0012 98 -31 66 -87 72 -73  
327 3 -0.0012 1 -98 66 -87 73 -74  
328 3 -0.0012 98 -31 66 -87 73 -74  
329 3 -0.0012 1 -98 66 -87 74 -29  
330 3 -0.0012 98 -31 66 -87 74 -29  
331 3 -0.0012 1 -98 87 -88 27 -71  
332 3 -0.0012 98 -31 87 -88 27 -71  
333 3 -0.0012 1 -98 87 -88 71 -72  
334 3 -0.0012 98 -31 87 -88 71 -72  
335 3 -0.0012 1 -98 87 -88 72 -73  
336 3 -0.0012 98 -31 87 -88 72 -73  
337 3 -0.0012 1 -98 87 -88 73 -74  
338 3 -0.0012 98 -31 87 -88 73 -74  
339 3 -0.0012 1 -98 87 -88 74 -29  
340 3 -0.0012 98 -31 87 -88 74 -29  
341 3 -0.0012 1 -98 88 -89 27 -71  
342 3 -0.0012 98 -31 88 -89 27 -71  
343 3 -0.0012 1 -98 88 -89 71 -72  
344 3 -0.0012 98 -31 88 -89 71 -72  
345 3 -0.0012 1 -98 88 -89 72 -73  
346 3 -0.0012 98 -31 88 -89 72 -73  
347 3 -0.0012 1 -98 88 -89 73 -74  
348 3 -0.0012 98 -31 88 -89 73 -74  
349 3 -0.0012 1 -98 88 -89 74 -29  
350 3 -0.0012 98 -31 88 -89 74 -29  
351 3 -0.0012 1 -98 89 -90 27 -71  
352 3 -0.0012 98 -31 89 -90 27 -71  
353 3 -0.0012 1 -98 89 -90 71 -72  
354 3 -0.0012 98 -31 89 -90 71 -72  
355 3 -0.0012 1 -98 89 -90 72 -73  
356 3 -0.0012 98 -31 89 -90 72 -73  
357 3 -0.0012 1 -98 89 -90 73 -74  
358 3 -0.0012 98 -31 89 -90 73 -74  
359 3 -0.0012 1 -98 89 -90 74 -29  
360 3 -0.0012 98 -31 89 -90 74 -29  
361 3 -0.0012 1 -98 90 -91 27 -71

362 3 -0.0012 98 -31 90 -91 27 -71  
363 3 -0.0012 1 -98 90 -91 71 -72  
364 3 -0.0012 98 -31 90 -91 71 -72  
365 3 -0.0012 1 -98 90 -91 72 -73  
366 3 -0.0012 98 -31 90 -91 72 -73  
367 3 -0.0012 1 -98 90 -91 73 -74  
368 3 -0.0012 98 -31 90 -91 73 -74  
369 3 -0.0012 1 -98 90 -91 74 -29  
370 3 -0.0012 98 -31 90 -91 74 -29  
371 3 -0.0012 1 -98 91 -92 27 -71  
372 3 -0.0012 98 -31 91 -92 27 -71  
373 3 -0.0012 1 -98 91 -92 71 -72  
374 3 -0.0012 98 -31 91 -92 71 -72  
375 3 -0.0012 1 -98 91 -92 72 -73  
376 3 -0.0012 98 -31 91 -92 72 -73  
377 3 -0.0012 1 -98 91 -92 73 -74  
378 3 -0.0012 98 -31 91 -92 73 -74  
379 3 -0.0012 1 -98 91 -92 74 -29  
380 3 -0.0012 98 -31 91 -92 74 -29  
381 3 -0.0012 1 -98 92 -93 27 -71  
382 3 -0.0012 98 -31 92 -93 27 -71  
383 3 -0.0012 1 -98 92 -93 71 -72  
384 3 -0.0012 98 -31 92 -93 71 -72  
385 3 -0.0012 1 -98 92 -93 72 -73  
386 3 -0.0012 98 -31 92 -93 72 -73  
387 3 -0.0012 1 -98 92 -93 73 -74  
388 3 -0.0012 98 -31 92 -93 73 -74  
389 3 -0.0012 1 -98 92 -93 74 -29  
390 3 -0.0012 98 -31 92 -93 74 -29  
391 3 -0.0012 1 -98 93 -94 27 -71  
392 3 -0.0012 98 -31 93 -94 27 -71  
393 3 -0.0012 1 -98 93 -94 71 -72  
394 3 -0.0012 98 -31 93 -94 71 -72  
395 3 -0.0012 1 -98 93 -94 72 -73  
396 3 -0.0012 98 -31 93 -94 72 -73  
397 3 -0.0012 1 -98 93 -94 73 -74  
398 3 -0.0012 98 -31 93 -94 73 -74  
399 3 -0.0012 1 -98 93 -94 74 -29  
400 3 -0.0012 98 -31 93 -94 74 -29  
401 3 -0.0012 1 -98 94 -95 27 -71  
402 3 -0.0012 98 -31 94 -95 27 -71  
403 3 -0.0012 1 -98 94 -95 71 -72  
404 3 -0.0012 98 -31 94 -95 71 -72  
405 3 -0.0012 1 -98 94 -95 72 -73  
406 3 -0.0012 98 -31 94 -95 72 -73  
407 3 -0.0012 1 -98 94 -95 73 -74  
408 3 -0.0012 98 -31 94 -95 73 -74  
409 3 -0.0012 1 -98 94 -95 74 -29  
410 3 -0.0012 98 -31 94 -95 74 -29  
411 3 -0.0012 1 -98 95 -96 27 -71  
412 3 -0.0012 98 -31 95 -96 27 -71  
413 3 -0.0012 1 -98 95 -96 71 -72  
414 3 -0.0012 98 -31 95 -96 71 -72  
415 3 -0.0012 1 -98 95 -96 72 -73  
416 3 -0.0012 98 -31 95 -96 72 -73  
417 3 -0.0012 1 -98 95 -96 73 -74  
418 3 -0.0012 98 -31 95 -96 73 -74  
419 3 -0.0012 1 -98 95 -96 74 -29  
420 3 -0.0012 98 -31 95 -96 74 -29  
421 3 -0.0012 1 -98 96 -97 27 -71  
422 3 -0.0012 98 -31 96 -97 27 -71

423 3 -0.0012 1 -98 96 -97 71 -72  
424 3 -0.0012 98 -31 96 -97 71 -72  
425 3 -0.0012 1 -98 96 -97 72 -73  
426 3 -0.0012 98 -31 96 -97 72 -73  
427 3 -0.0012 1 -98 96 -97 73 -74  
428 3 -0.0012 98 -31 96 -97 73 -74  
429 3 -0.0012 1 -98 96 -97 74 -29  
430 3 -0.0012 98 -31 96 -97 74 -29  
431 3 -.0012 31 -38 37 35 -34 -23  
432 3 -.0012 31 -38 35 23 -27 -25  
433 3 -.0012 31 -38 27 -29 23 -25  
434 3 -.0012 31 -38 29 -34 23 -25  
435 3 -.0012 31 -38 29 -34 25 -36  
436 3 -.0012 31 -38 25 -36 -29 27  
437 3 -.0012 31 -38 35 -27 25 -36  
438 3 -0.0012 1 -98 27 -71 97 -99  
439 3 -0.0012 98 -31 27 -71 97 -99  
440 3 -0.0012 1 -98 71 -72 97 -99  
441 3 -0.0012 98 -31 71 -72 97 -99  
442 3 -0.0012 1 -98 72 -73 97 -99  
443 3 -0.0012 98 -31 72 -73 97 -99  
444 3 -0.0012 1 -98 73 -74 97 -99  
445 3 -0.0012 98 -31 73 -74 97 -99  
446 3 -0.0012 1 -98 74 -29 97 -99  
447 3 -0.0012 98 -31 74 -29 97 -99  
448 3 -0.0012 1 -98 27 -71 99 -100  
449 3 -0.0012 98 -31 27 -71 99 -100  
450 3 -0.0012 1 -98 71 -72 99 -100  
451 3 -0.0012 98 -31 71 -72 99 -100  
452 3 -0.0012 1 -98 72 -73 99 -100  
453 3 -0.0012 98 -31 72 -73 99 -100  
454 3 -0.0012 1 -98 73 -74 99 -100  
455 3 -0.0012 98 -31 73 -74 99 -100  
456 3 -0.0012 1 -98 74 -29 99 -100  
457 3 -0.0012 98 -31 74 -29 99 -100  
458 3 -0.0012 1 -98 27 -71 100 -101  
459 3 -0.0012 98 -31 27 -71 100 -101  
460 3 -0.0012 1 -98 71 -72 100 -101  
461 3 -0.0012 98 -31 71 -72 100 -101  
462 3 -0.0012 1 -98 72 -73 100 -101  
463 3 -0.0012 98 -31 72 -73 100 -101  
464 3 -0.0012 1 -98 73 -74 100 -101  
465 3 -0.0012 98 -31 73 -74 100 -101  
466 3 -0.0012 1 -98 74 -29 100 -101  
467 3 -0.0012 98 -31 74 -29 100 -101  
468 3 -0.0012 1 -98 27 -71 101 -102  
469 3 -0.0012 98 -31 27 -71 101 -102  
470 3 -0.0012 1 -98 71 -72 101 -102  
471 3 -0.0012 98 -31 71 -72 101 -102  
472 3 -0.0012 1 -98 72 -73 101 -102  
473 3 -0.0012 98 -31 72 -73 101 -102  
474 3 -0.0012 1 -98 73 -74 101 -102  
475 3 -0.0012 98 -31 73 -74 101 -102  
476 3 -0.0012 1 -98 74 -29 101 -102  
477 3 -0.0012 98 -31 74 -29 101 -102  
478 3 -0.0012 1 -98 27 -71 102 -103  
479 3 -0.0012 98 -31 27 -71 102 -103  
480 3 -0.0012 1 -98 71 -72 102 -103  
481 3 -0.0012 98 -31 71 -72 102 -103  
482 3 -0.0012 1 -98 72 -73 102 -103  
483 3 -0.0012 98 -31 72 -73 102 -103

484 3 -0.0012 1 -98 73 -74 102 -103  
485 3 -0.0012 98 -31 73 -74 102 -103  
486 3 -0.0012 1 -98 74 -29 102 -103  
487 3 -0.0012 98 -31 74 -29 102 -103  
488 3 -0.0012 1 -98 27 -71 103 -104  
489 3 -0.0012 98 -31 27 -71 103 -104  
490 3 -0.0012 1 -98 71 -72 103 -104  
491 3 -0.0012 98 -31 71 -72 103 -104  
492 3 -0.0012 1 -98 72 -73 103 -104  
493 3 -0.0012 98 -31 72 -73 103 -104  
494 3 -0.0012 1 -98 73 -74 103 -104  
495 3 -0.0012 98 -31 73 -74 103 -104  
496 3 -0.0012 1 -98 74 -29 103 -104  
497 3 -0.0012 98 -31 74 -29 103 -104  
498 3 -0.0012 1 -98 27 -71 104 -105  
499 3 -0.0012 98 -31 27 -71 104 -105  
500 3 -0.0012 1 -98 71 -72 104 -105  
501 3 -0.0012 98 -31 71 -72 104 -105  
502 3 -0.0012 1 -98 72 -73 104 -105  
503 3 -0.0012 98 -31 72 -73 104 -105  
504 3 -0.0012 1 -98 73 -74 104 -105  
505 3 -0.0012 98 -31 73 -74 104 -105  
506 3 -0.0012 1 -98 74 -29 104 -105  
507 3 -0.0012 98 -31 74 -29 104 -105  
508 3 -0.0012 1 -98 27 -71 105 -106  
509 3 -0.0012 98 -31 27 -71 105 -106  
510 3 -0.0012 1 -98 71 -72 105 -106  
511 3 -0.0012 98 -31 71 -72 105 -106  
512 3 -0.0012 1 -98 72 -73 105 -106  
513 3 -0.0012 98 -31 72 -73 105 -106  
514 3 -0.0012 1 -98 73 -74 105 -106  
515 3 -0.0012 98 -31 73 -74 105 -106  
516 3 -0.0012 1 -98 74 -29 105 -106  
517 3 -0.0012 98 -31 74 -29 105 -106  
518 3 -0.0012 1 -98 27 -71 106 -107  
519 3 -0.0012 98 -31 27 -71 106 -107  
520 3 -0.0012 1 -98 71 -72 106 -107  
521 3 -0.0012 98 -31 71 -72 106 -107  
522 3 -0.0012 1 -98 72 -73 106 -107  
523 3 -0.0012 98 -31 72 -73 106 -107  
524 3 -0.0012 1 -98 73 -74 106 -107  
525 3 -0.0012 98 -31 73 -74 106 -107  
526 3 -0.0012 1 -98 74 -29 106 -107  
527 3 -0.0012 98 -31 74 -29 106 -107  
528 3 -0.0012 1 -98 27 -71 107 -108  
529 3 -0.0012 98 -31 27 -71 107 -108  
530 3 -0.0012 1 -98 71 -72 107 -108  
531 3 -0.0012 98 -31 71 -72 107 -108  
532 3 -0.0012 1 -98 72 -73 107 -108  
533 3 -0.0012 98 -31 72 -73 107 -108  
534 3 -0.0012 1 -98 73 -74 107 -108  
535 3 -0.0012 98 -31 73 -74 107 -108  
536 3 -0.0012 1 -98 74 -29 107 -108  
537 3 -0.0012 98 -31 74 -29 107 -108  
538 3 -0.0012 1 -98 27 -71 108 -109  
539 3 -0.0012 98 -31 27 -71 108 -109  
540 3 -0.0012 1 -98 71 -72 108 -109  
541 3 -0.0012 98 -31 71 -72 108 -109  
542 3 -0.0012 1 -98 72 -73 108 -109  
543 3 -0.0012 98 -31 72 -73 108 -109  
544 3 -0.0012 1 -98 73 -74 108 -109



545 3 -0.0012 98 -31 73 -74 108 -109  
546 3 -0.0012 1 -98 74 -29 108 -109  
547 3 -0.0012 98 -31 74 -29 108 -109  
548 3 -0.0012 1 -98 27 -71 109 -110  
549 3 -0.0012 98 -31 27 -71 109 -110  
550 3 -0.0012 1 -98 71 -72 109 -110  
551 3 -0.0012 98 -31 71 -72 109 -110  
552 3 -0.0012 1 -98 72 -73 109 -110  
553 3 -0.0012 98 -31 72 -73 109 -110  
554 3 -0.0012 1 -98 73 -74 109 -110  
555 3 -0.0012 98 -31 73 -74 109 -110  
556 3 -0.0012 1 -98 74 -29 109 -110  
557 3 -0.0012 98 -31 74 -29 109 -110  
558 3 -0.0012 1 -98 27 -71 110 -111  
559 3 -0.0012 98 -31 27 -71 110 -111  
560 3 -0.0012 1 -98 71 -72 110 -111  
561 3 -0.0012 98 -31 71 -72 110 -111  
562 3 -0.0012 1 -98 72 -73 110 -111  
563 3 -0.0012 98 -31 72 -73 110 -111  
564 3 -0.0012 1 -98 73 -74 110 -111  
565 3 -0.0012 98 -31 73 -74 110 -111  
566 3 -0.0012 1 -98 74 -29 110 -111  
567 3 -0.0012 98 -31 74 -29 110 -111  
568 3 -0.0012 1 -98 27 -71 111 -112  
569 3 -0.0012 98 -31 27 -71 111 -112  
570 3 -0.0012 1 -98 71 -72 111 -112  
571 3 -0.0012 98 -31 71 -72 111 -112  
572 3 -0.0012 1 -98 72 -73 111 -112  
573 3 -0.0012 98 -31 72 -73 111 -112  
574 3 -0.0012 1 -98 73 -74 111 -112  
575 3 -0.0012 98 -31 73 -74 111 -112  
576 3 -0.0012 1 -98 74 -29 111 -112  
577 3 -0.0012 98 -31 74 -29 111 -112  
578 3 -0.0012 1 -98 27 -71 112 -113  
579 3 -0.0012 98 -31 27 -71 112 -113  
580 3 -0.0012 1 -98 71 -72 112 -113  
581 3 -0.0012 98 -31 71 -72 112 -113  
582 3 -0.0012 1 -98 72 -73 112 -113  
583 3 -0.0012 98 -31 72 -73 112 -113  
584 3 -0.0012 1 -98 73 -74 112 -113  
585 3 -0.0012 98 -31 73 -74 112 -113  
586 3 -0.0012 1 -98 74 -29 112 -113  
587 3 -0.0012 98 -31 74 -29 112 -113  
588 3 -0.0012 1 -98 27 -71 113 -114  
589 3 -0.0012 98 -31 27 -71 113 -114  
590 3 -0.0012 1 -98 71 -72 113 -114  
591 3 -0.0012 98 -31 71 -72 113 -114  
592 3 -0.0012 1 -98 72 -73 113 -114  
593 3 -0.0012 98 -31 72 -73 113 -114  
594 3 -0.0012 1 -98 73 -74 113 -114  
595 3 -0.0012 98 -31 73 -74 113 -114  
596 3 -0.0012 1 -98 74 -29 113 -114  
597 3 -0.0012 98 -31 74 -29 113 -114  
598 3 -0.0012 1 -98 27 -71 114 -115  
599 3 -0.0012 98 -31 27 -71 114 -115  
600 3 -0.0012 1 -98 71 -72 114 -115  
601 3 -0.0012 98 -31 71 -72 114 -115  
602 3 -0.0012 1 -98 72 -73 114 -115  
603 3 -0.0012 98 -31 72 -73 114 -115  
604 3 -0.0012 1 -98 73 -74 114 -115  
605 3 -0.0012 98 -31 73 -74 114 -115

606 3 -0.0012 1 -98 74 -29 114 -115  
607 3 -0.0012 98 -31 74 -29 114 -115  
608 3 -0.0012 1 -98 27 -71 115 -116  
609 3 -0.0012 98 -31 27 -71 115 -116  
610 3 -0.0012 1 -98 71 -72 115 -116  
611 3 -0.0012 98 -31 71 -72 115 -116  
612 3 -0.0012 1 -98 72 -73 115 -116  
613 3 -0.0012 98 -31 72 -73 115 -116  
614 3 -0.0012 1 -98 73 -74 115 -116  
615 3 -0.0012 98 -31 73 -74 115 -116  
616 3 -0.0012 1 -98 74 -29 115 -116  
617 3 -0.0012 98 -31 74 -29 115 -116  
618 3 -0.0012 1 -98 27 -71 116 -117  
619 3 -0.0012 98 -31 27 -71 116 -117  
620 3 -0.0012 1 -98 71 -72 116 -117  
621 3 -0.0012 98 -31 71 -72 116 -117  
622 3 -0.0012 1 -98 72 -73 116 -117  
623 3 -0.0012 98 -31 72 -73 116 -117  
624 3 -0.0012 1 -98 73 -74 116 -117  
625 3 -0.0012 98 -31 73 -74 116 -117  
626 3 -0.0012 1 -98 74 -29 116 -117  
627 3 -0.0012 98 -31 74 -29 116 -117  
628 3 -0.0012 1 -98 27 -71 117 -118  
629 3 -0.0012 98 -31 27 -71 117 -118  
630 3 -0.0012 1 -98 71 -72 117 -118  
631 3 -0.0012 98 -31 71 -72 117 -118  
632 3 -0.0012 1 -98 72 -73 117 -118  
633 3 -0.0012 98 -31 72 -73 117 -118  
634 3 -0.0012 1 -98 73 -74 117 -118  
635 3 -0.0012 98 -31 73 -74 117 -118  
636 3 -0.0012 1 -98 74 -29 117 -118  
637 3 -0.0012 98 -31 74 -29 117 -118  
638 3 -0.0012 1 -98 27 -71 118 -119  
639 3 -0.0012 98 -31 27 -71 118 -119  
640 3 -0.0012 1 -98 71 -72 118 -119  
641 3 -0.0012 98 -31 71 -72 118 -119  
642 3 -0.0012 1 -98 72 -73 118 -119  
643 3 -0.0012 98 -31 72 -73 118 -119  
644 3 -0.0012 1 -98 73 -74 118 -119  
645 3 -0.0012 98 -31 73 -74 118 -119  
646 3 -0.0012 1 -98 74 -29 118 -119  
647 3 -0.0012 98 -31 74 -29 118 -119  
648 3 -0.0012 1 -98 27 -71 119 -120  
649 3 -0.0012 98 -31 27 -71 119 -120  
650 3 -0.0012 1 -98 71 -72 119 -120  
651 3 -0.0012 98 -31 71 -72 119 -120  
652 3 -0.0012 1 -98 72 -73 119 -120  
653 3 -0.0012 98 -31 72 -73 119 -120  
654 3 -0.0012 1 -98 73 -74 119 -120  
655 3 -0.0012 98 -31 73 -74 119 -120  
656 3 -0.0012 1 -98 74 -29 119 -120  
657 3 -0.0012 98 -31 74 -29 119 -120  
658 3 -0.0012 1 -98 27 -71 120 -121  
659 3 -0.0012 98 -31 27 -71 120 -121  
660 3 -0.0012 1 -98 71 -72 120 -121  
661 3 -0.0012 98 -31 71 -72 120 -121  
662 3 -0.0012 1 -98 72 -73 120 -121  
663 3 -0.0012 98 -31 72 -73 120 -121  
664 3 -0.0012 1 -98 73 -74 120 -121  
665 3 -0.0012 98 -31 73 -74 120 -121  
666 3 -0.0012 1 -98 74 -29 120 -121

667 3 -0.0012 98 -31 74 -29 120 -121  
668 3 -0.0012 1 -98 27 -71 121 -122  
669 3 -0.0012 98 -31 27 -71 121 -122  
670 3 -0.0012 1 -98 71 -72 121 -122  
671 3 -0.0012 98 -31 71 -72 121 -122  
672 3 -0.0012 1 -98 72 -73 121 -122  
673 3 -0.0012 98 -31 72 -73 121 -122  
674 3 -0.0012 1 -98 73 -74 121 -122  
675 3 -0.0012 98 -31 73 -74 121 -122  
676 3 -0.0012 1 -98 74 -29 121 -122  
677 3 -0.0012 98 -31 74 -29 121 -122  
678 3 -0.0012 1 -98 27 -71 122 -123  
679 3 -0.0012 98 -31 27 -71 122 -123  
680 3 -0.0012 1 -98 71 -72 122 -123  
681 3 -0.0012 98 -31 71 -72 122 -123  
682 3 -0.0012 1 -98 72 -73 122 -123  
683 3 -0.0012 98 -31 72 -73 122 -123  
684 3 -0.0012 1 -98 73 -74 122 -123  
685 3 -0.0012 98 -31 73 -74 122 -123  
686 3 -0.0012 1 -98 74 -29 122 -123  
687 3 -0.0012 98 -31 74 -29 122 -123  
688 3 -0.0012 1 -98 27 -71 123 -124  
689 3 -0.0012 98 -31 27 -71 123 -124  
690 3 -0.0012 1 -98 71 -72 123 -124  
691 3 -0.0012 98 -31 71 -72 123 -124  
692 3 -0.0012 1 -98 72 -73 123 -124  
693 3 -0.0012 98 -31 72 -73 123 -124  
694 3 -0.0012 1 -98 73 -74 123 -124  
695 3 -0.0012 98 -31 73 -74 123 -124  
696 3 -0.0012 1 -98 74 -29 123 -124  
697 3 -0.0012 98 -31 74 -29 123 -124  
698 3 -0.0012 1 -98 27 -71 124 -125  
699 3 -0.0012 98 -31 27 -71 124 -125  
700 3 -0.0012 1 -98 71 -72 124 -125  
701 3 -0.0012 98 -31 71 -72 124 -125  
702 3 -0.0012 1 -98 72 -73 124 -125  
703 3 -0.0012 98 -31 72 -73 124 -125  
704 3 -0.0012 1 -98 73 -74 124 -125  
705 3 -0.0012 98 -31 73 -74 124 -125  
706 3 -0.0012 1 -98 74 -29 124 -125  
707 3 -0.0012 98 -31 74 -29 124 -125  
708 3 -0.0012 1 -98 27 -71 125 -126  
709 3 -0.0012 98 -31 27 -71 125 -126  
710 3 -0.0012 1 -98 71 -72 125 -126  
711 3 -0.0012 98 -31 71 -72 125 -126  
712 3 -0.0012 1 -98 72 -73 125 -126  
713 3 -0.0012 98 -31 72 -73 125 -126  
714 3 -0.0012 1 -98 73 -74 125 -126  
715 3 -0.0012 98 -31 73 -74 125 -126  
716 3 -0.0012 1 -98 74 -29 125 -126  
717 3 -0.0012 98 -31 74 -29 125 -126  
718 3 -0.0012 1 -98 27 -71 126 -127  
719 3 -0.0012 98 -31 27 -71 126 -127  
720 3 -0.0012 1 -98 71 -72 126 -127  
721 3 -0.0012 98 -31 71 -72 126 -127  
722 3 -0.0012 1 -98 72 -73 126 -127  
723 3 -0.0012 98 -31 72 -73 126 -127  
724 3 -0.0012 1 -98 73 -74 126 -127  
725 3 -0.0012 98 -31 73 -74 126 -127  
726 3 -0.0012 1 -98 74 -29 126 -127  
727 3 -0.0012 98 -31 74 -29 126 -127

728 3 -0.0012 1 -98 27 -71 127 -128  
729 3 -0.0012 98 -31 27 -71 127 -128  
730 3 -0.0012 1 -98 71 -72 127 -128  
731 3 -0.0012 98 -31 71 -72 127 -128  
732 3 -0.0012 1 -98 72 -73 127 -128  
733 3 -0.0012 98 -31 72 -73 127 -128  
734 3 -0.0012 1 -98 73 -74 127 -128  
735 3 -0.0012 98 -31 73 -74 127 -128  
736 3 -0.0012 1 -98 74 -29 127 -128  
737 3 -0.0012 98 -31 74 -29 127 -128  
738 3 -0.0012 1 -98 27 -71 128 -129  
739 3 -0.0012 98 -31 27 -71 128 -129  
740 3 -0.0012 1 -98 71 -72 128 -129  
741 3 -0.0012 98 -31 71 -72 128 -129  
742 3 -0.0012 1 -98 72 -73 128 -129  
743 3 -0.0012 98 -31 72 -73 128 -129  
744 3 -0.0012 1 -98 73 -74 128 -129  
745 3 -0.0012 98 -31 73 -74 128 -129  
746 3 -0.0012 1 -98 74 -29 128 -129  
747 3 -0.0012 98 -31 74 -29 128 -129  
748 3 -0.0012 1 -98 27 -71 129 -130  
749 3 -0.0012 98 -31 27 -71 129 -130  
750 3 -0.0012 1 -98 71 -72 129 -130  
751 3 -0.0012 98 -31 71 -72 129 -130  
752 3 -0.0012 1 -98 72 -73 129 -130  
753 3 -0.0012 98 -31 72 -73 129 -130  
754 3 -0.0012 1 -98 73 -74 129 -130  
755 3 -0.0012 98 -31 73 -74 129 -130  
756 3 -0.0012 1 -98 74 -29 129 -130  
757 3 -0.0012 98 -31 74 -29 129 -130  
758 3 -0.0012 1 -98 27 -71 130 -131  
759 3 -0.0012 98 -31 27 -71 130 -131  
760 3 -0.0012 1 -98 71 -72 130 -131  
761 3 -0.0012 98 -31 71 -72 130 -131  
762 3 -0.0012 1 -98 72 -73 130 -131  
763 3 -0.0012 98 -31 72 -73 130 -131  
764 3 -0.0012 1 -98 73 -74 130 -131  
765 3 -0.0012 98 -31 73 -74 130 -131  
766 3 -0.0012 1 -98 74 -29 130 -131  
767 3 -0.0012 98 -31 74 -29 130 -131  
768 3 -0.0012 1 -98 27 -71 131 -132  
769 3 -0.0012 98 -31 27 -71 131 -132  
770 3 -0.0012 1 -98 71 -72 131 -132  
771 3 -0.0012 98 -31 71 -72 131 -132  
772 3 -0.0012 1 -98 72 -73 131 -132  
773 3 -0.0012 98 -31 72 -73 131 -132  
774 3 -0.0012 1 -98 73 -74 131 -132  
775 3 -0.0012 98 -31 73 -74 131 -132  
776 3 -0.0012 1 -98 74 -29 131 -132  
777 3 -0.0012 98 -31 74 -29 131 -132  
778 3 -0.0012 1 -98 27 -71 132 -133  
779 3 -0.0012 98 -31 27 -71 132 -133  
780 3 -0.0012 1 -98 71 -72 132 -133  
781 3 -0.0012 98 -31 71 -72 132 -133  
782 3 -0.0012 1 -98 72 -73 132 -133  
783 3 -0.0012 98 -31 72 -73 132 -133  
784 3 -0.0012 1 -98 73 -74 132 -133  
785 3 -0.0012 98 -31 73 -74 132 -133  
786 3 -0.0012 1 -98 74 -29 132 -133  
787 3 -0.0012 98 -31 74 -29 132 -133  
788 3 -0.0012 1 -98 27 -71 133 -134

789 3 -0.0012 98 -31 27 -71 133 -134  
 790 3 -0.0012 1 -98 71 -72 133 -134  
 791 3 -0.0012 98 -31 71 -72 133 -134  
 792 3 -0.0012 1 -98 72 -73 133 -134  
 793 3 -0.0012 98 -31 72 -73 133 -134  
 794 3 -0.0012 1 -98 73 -74 133 -134  
 795 3 -0.0012 98 -31 73 -74 133 -134  
 796 3 -0.0012 1 -98 74 -29 133 -134  
 797 3 -0.0012 98 -31 74 -29 133 -134  
 798 3 -0.0012 1 -98 27 -71 134 -36  
 799 3 -0.0012 98 -31 27 -71 134 -36  
 800 3 -0.0012 1 -98 71 -72 134 -36  
 801 3 -0.0012 98 -31 71 -72 134 -36  
 802 3 -0.0012 1 -98 72 -73 134 -36  
 803 3 -0.0012 98 -31 72 -73 134 -36  
 804 3 -0.0012 1 -98 73 -74 134 -36  
 805 3 -0.0012 98 -31 73 -74 134 -36  
 806 3 -0.0012 1 -98 74 -29 134 -36  
 807 3 -0.0012 98 -31 74 -29 134 -36

#### c Surface Definitions

1 pz 0 \$Bioshield Base  
 2 px 347.98 \$East Bioshield Base  
 3 px -190.5 \$West Bioshield Base  
 4 py 346.63 \$North Bioshield Base  
 5 py -346.63 \$South Bioshield Base  
 6 pz 369.718 \$Bioshield Base top  
 c 7 1 py 346.63 \$North East Corner, Transformation 1  
 c 8 2 py 346.63 \$North West Corner, Transformation 2  
 c 9 3 py -346.63 \$South East Corner, Transformation 3  
 c 10 4 py -346.63 \$South West Corner, Transformation 4  
 11 pz 739.436 \$Top of Reactor  
 12 pz 655.32 \$Top of Cylinder (middle layer)  
 13 cz 190.5 \$Reactor Bioshield Cylinder  
 14 px -515.62 \$West outside wall PIF  
 16 px -290.5 \$East inside wall PIF  
 17 py 246.63 \$North outside wall PIF  
 18 py 146.63 \$North inside wall PIF  
 19 py -246.63 \$South outside wall PIF  
 20 py -146.63 \$South inside wall PIF  
 21 px -415.63 \$West inside wall PIF  
 22 px -759.46 \$West Inside Wall  
 23 px -779.78 \$West Outside Wall  
 24 px 1221.7 \$East Inside Wall  
 25 px 1242.1 \$East Outside Wall  
 26 py -836.85 \$South Inside Wall  
 27 py -857.17 \$South Outside Wall  
 28 py 836.85 \$North Inside Wall  
 29 py 857.17 \$North Outside Wall  
 30 pz 944.88 \$Ceiling Bottom - Stainless Steel  
 31 pz 945.198 \$Ceiling Top  
 32 cz 99.06 \$Inside Bioshield Cylinder  
 33 pz 365.76 \$PIF TOP  
 34 py 5240 \$North Outside Field  
 35 py -5240 \$South Outside Field  
 36 px 7242.1 \$East Outside Field  
 37 px -5240 \$West Outside Field  
 38 pz 1500 \$Top most plane of air above reactor building.  
 39 cz 63.5 \$Core Cylinder  
 40 pz 91.44 \$Bottom plane for core cylinder  
 41 pz 144.78 \$Top plane for core cylinder

42 pz 154.94 \$Top plane 1st Air Cylinder  
43 pz 175.26 \$Bottom plane for 2nd air cylinder  
44 pz 185.42 \$Top plane for 2nd air cylinder  
45 pz 205.74 \$Bottom plane for 3rd air cylinder  
46 pz 215.90 \$Top plane for 3rd air cylinder  
47 pz 236.22 \$Bottom plane for 4th air cylinder  
48 pz 246.38 \$Top plane for 4th air cylinder  
49 pz 261.62 \$Bottom plane for 5th air cylinder  
50 pz 271.78 \$Top plane for 5th air cylinder  
51 pz 292.10 \$Bottom plane for 6th air cylinder  
52 pz 302.26 \$Top plane for 6th air cylinder  
53 cz 10.16 \$Air Test Cylinder  
54 pz 729.276 \$Air cylinder top of core cylinder  
55 px -1979.78  
56 px -1679.78  
57 px -1379.78  
58 px -1079.78  
59 px -375.4  
60 px 28.98  
61 px 433.36  
62 px 837.74  
63 px 1542.1  
64 px 1842.1  
65 px 2142.1  
66 px 2442.1  
67 py -2057.17  
68 py -1757.17  
69 py -1457.17  
70 py -1157.17  
71 py -514.3  
72 py -171.43  
73 py 171.43  
74 py 514.3  
75 py 1157.17  
76 py 1457.17  
77 py 1757.17  
78 py 2057.17  
79 px 1342.1  
80 px 1442.1  
81 px 1642.1  
82 px 1742.2  
83 px 1942.1  
84 px 2042.1  
85 px 2242.1  
86 px 2342.1  
87 px 2542.1  
88 px 2642.1  
89 px 2742.1  
90 px 2842.1  
91 px 2942.1  
92 px 3042.1  
93 px 3142.1  
94 px 3242.1  
95 px 3342.1  
96 px 3442.1  
97 px 3542.1  
98 pz 100 \$Plane to split external cells into sections up to 1 meter, then above 1 meter  
99 px 3642.1  
100 px 3742.1  
101 px 3842.1  
102 px 3942.1

103 px 4042.1  
 104 px 4142.1  
 105 px 4242.1  
 106 px 4342.1  
 107 px 4442.1  
 108 px 4542.1  
 109 px 4642.1  
 110 px 4742.1  
 111 px 4842.1  
 112 px 4942.1  
 113 px 5042.1  
 114 px 5142.1  
 115 px 5242.1  
 116 px 5342.1  
 117 px 5442.1  
 118 px 5542.1  
 119 px 5642.1  
 120 px 5742.1  
 121 px 5842.1  
 122 px 5942.1  
 123 px 6042.1  
 124 px 6142.1  
 125 px 6242.1  
 126 px 6342.1  
 127 px 6442.1  
 128 px 6542.1  
 129 px 6642.1  
 130 px 6742.1  
 131 px 6842.1  
 132 px 6942.1  
 133 px 7042.1  
 134 px 7142.1

c Material Definitions

mode p

m1 020040 43.5 \$ Calcium Cement (atom ratio)

008016 77.6 \$ Oxygen

014028 14.1 \$ Si

013027 3.04 \$ Al

026056 1 \$ Fe

m2 001001 2 \$Water (H)

008016 1 \$Water (O)

m3 015031 3 \$Air (N)

008016 1 \$Air (O)

m4 026056 70 \$Iron

006012 8 \$Carbon

024052 18 \$Chromium

025055 1 \$Manganese

014028 1 \$Silicon

015030 1 \$Phosphorus

016032 1 \$Sulfur

sdef ERG=D1 POS=0 0 144 AXS=0 0 1 CELL=35 RAD=D2 VEC=0 0 1 DIR=1

sl1 H 0 1 2 3 5 7.5 10 \$particle distribution

sp1 D 0 0.692329 0.2492384 0.0498477 0.0069233 0.0013847 0.0002769

sl2 64

\*f8:p 39 41 43 45 47 49 52 201 202 203 204 205 206 207 208 209 210 211 212

213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229

230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246

247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263

264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280

281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297







## B APPENDIX – PARTIAL MCNP5 OUTPUT FOR LOCA SIMULATION; MeV/photon

1tally 8 nps = 10000000  
tally type 8\* energy deposition units mev  
tally for photons

cell 39	7.65668E-06	0.0344
cell 41	7.20878E-06	0.0149
cell 43	6.94475E-06	0.0154
cell 45	6.85553E-06	0.0153
cell 47	6.94157E-06	0.0154
cell 49	6.77631E-06	0.0160
cell 52	6.50256E-06	0.0079
cell 201	1.39436E-10	1.0000
cell 202	7.43429E-09	0.6079
cell 203	4.37828E-10	0.7298
cell 204	1.41857E-08	0.3562
cell 205	1.32356E-09	0.2363
cell 206	-5.03121E-09	0.9964
cell 207	4.78594E-10	0.6603
cell 208	-2.51188E-09	1.0000
cell 209	-1.34325E-10	1.0000
cell 210	8.83095E-09	0.5410
cell 211	4.29245E-10	0.5479
cell 212	3.52819E-09	1.0000
cell 213	6.34917E-10	0.4733
cell 214	3.33833E-08	0.2746
cell 215	4.00725E-10	0.8159
cell 216	2.96418E-08	0.3197
cell 217	-3.53989E-10	0.8462
cell 218	1.96204E-08	0.4699
cell 219		

1.64792E-10 1.0000  
cell 220  
2.07251E-08 0.4031  
cell 221  
-1.26952E-10 1.0000  
cell 222  
1.46046E-08 0.5619  
cell 223  
-2.17286E-11 1.0000  
cell 224  
3.11102E-08 0.293  
cell 225  
4.11697E-10 0.6373  
cell 226  
1.99363E-08 0.4714  
cell 227  
3.60497E-10 0.8468  
cell 228  
1.87417E-08 0.4802  
cell 229  
-1.22580E-10 1.0000  
cell 230  
6.66424E-09 1.0000  
cell 231  
-3.99503E-10 0.6044  
cell 232  
1.99555E-08 0.377  
cell 233  
-1.28134E-10 1.0000  
cell 234  
1.11121E-08 0.7485  
cell 235  
-3.52650E-11 1.0000  
cell 236  
3.95310E-08 0.2181  
cell 237  
2.47073E-10 1.0000  
cell 238  
1.62465E-08 0.5176  
cell 239  
7.84070E-11 1.0000  
cell 240  
2.46931E-08 0.3068  
cell 241  
1.38994E-10 1.0000  
cell 242  
1.89453E-08 0.3790  
cell 243  
2.72911E-10 0.8389  
cell 244  
2.17084E-08 0.3626  
cell 245  
2.55192E-10 0.9646  
cell 246  
3.00641E-08 0.2661  
cell 247  
-1.64902E-10 1.0000  
cell 248  
1.48509E-08 0.5228  
cell 249  
3.13994E-10 0.6905

cell 250  
2.77053E-08 0.2566  
cell 251  
4.96144E-10 0.4039  
cell 252  
1.59292E-08 0.4224  
cell 253  
6.15501E-11 1.0000  
cell 254  
3.11376E-08 0.2343  
cell 255  
4.06298E-10 0.5670  
cell 256  
2.65631E-08 0.2832  
cell 257  
2.87032E-10 0.7449  
cell 258  
2.88546E-08 0.2521  
cell 259  
6.30261E-10 0.3253  
cell 260  
1.67573E-08 0.4011  
cell 261  
2.38478E-10 0.7936  
cell 262  
1.78655E-08 0.3545  
cell 263  
4.85098E-10 0.4267  
cell 264  
3.17767E-08 0.2168  
cell 265  
2.95688E-10 0.7331  
cell 266  
3.08311E-08 0.2252  
cell 267  
5.25865E-10 0.3663  
cell 268  
1.82452E-08 0.3762  
cell 269  
2.00140E-10 0.9771  
cell 270  
2.53563E-08 0.2494  
cell 271  
3.71482E-10 0.5621  
cell 272  
3.02393E-08 0.1977  
cell 273  
4.21626E-10 0.4553  
cell 274  
2.18579E-08 0.2916  
cell 275  
3.65036E-10 0.5886  
cell 276  
2.50815E-08 0.2599  
cell 277  
5.17164E-10 0.4153  
cell 278  
3.86343E-08 0.1632  
cell 279  
5.08859E-10 0.3397  
cell 280

2.49583E-08 0.2376  
cell 281  
4.71245E-10 0.3944  
cell 282  
2.86224E-08 0.1982  
cell 283  
2.62623E-10 0.7536  
cell 284  
2.60212E-08 0.2282  
cell 285  
3.66666E-10 0.5249  
cell 286  
3.91958E-08 0.1534  
cell 287  
2.20130E-10 0.8068  
cell 288  
2.86248E-08 0.2054  
cell 289  
4.66464E-10 0.4418  
cell 290  
2.05945E-08 0.2722  
cell 291  
6.03475E-10 0.3076  
cell 292  
2.64717E-08 0.1973  
cell 293  
7.31498E-10 0.2479  
cell 294  
2.49366E-08 0.2297  
cell 295  
3.34122E-10 0.6148  
cell 296  
3.41430E-08 0.1683  
  
cell 297  
4.33002E-10 0.3942  
  
cell 298  
3.09322E-08 0.1805  
  
cell 299  
6.80865E-10 0.2939  
cell 300  
3.13115E-08 0.1694  
cell 301  
4.23048E-10 0.4084  
cell 302  
3.44367E-08 0.1464  
cell 303  
5.33460E-10 0.3806  
cell 304  
4.07613E-08 0.1313  
cell 305  
3.93170E-10 0.3782  
cell 306  
3.58571E-08 0.1497  
cell 307  
2.93220E-10 0.6930  
cell 308  
2.65651E-08 0.2003  
cell 309

3.15720E-10 0.5132  
cell 310  
2.09667E-08 0.2427  
cell 311  
5.48451E-10 0.3133  
cell 312  
2.18636E-08 0.2191  
cell 313  
1.12008E-10 1.0000  
cell 314  
3.01675E-08 0.1666  
cell 315  
3.85597E-10 0.4089  
cell 316  
3.06600E-08 0.1664  
cell 317  
5.29915E-10 0.3981  
cell 318  
3.08015E-08 0.1625  
cell 319  
3.90866E-10 0.5512  
cell 320  
3.47770E-08 0.1368  
cell 321  
4.40564E-10 0.3433  
cell 322  
3.14917E-08 0.1418  
cell 323  
5.09665E-10 0.3178  
cell 324  
2.76440E-08 0.1716  
cell 325  
3.17765E-10 0.5596  
cell 326  
2.36935E-08 0.2063  
cell 327  
5.53683E-10 0.2945  
cell 328  
2.45148E-08 0.1956  
cell 329  
4.45389E-10 0.4034  
cell 330  
1.92757E-08 0.2343  
cell 331  
5.70171E-10 0.2779  
cell 332  
2.71441E-08 0.1607  
cell 333  
5.17316E-10 0.3077  
cell 334  
3.36814E-08 0.1337  
cell 335  
5.23937E-10 0.3610  
cell 336  
4.09290E-08 0.1109  
cell 337  
3.00546E-10 0.5807  
cell 338  
2.74646E-08 0.1646  
cell 339  
5.26832E-10 0.2969

cell 340  
2.18903E-08 0.1950  
cell 341  
6.44296E-10 0.2518  
cell 342  
2.78755E-08 0.1435  
cell 343  
4.00803E-10 0.4047  
cell 344  
2.36723E-08 0.1819  
cell 345  
4.10131E-10 0.4346  
cell 346  
2.68172E-08 0.1618  
cell 347  
8.15785E-10 0.1998  
cell 348  
2.72027E-08 0.1569  
cell 349  
4.71551E-10 0.3195  
cell 350  
3.40523E-08 0.1237  
cell 351  
3.79162E-10 0.3906  
cell 352  
2.23201E-08 0.1747  
cell 353  
5.51137E-10 0.3047  
cell 354  
1.81807E-08 0.2299  
cell 355  
7.21411E-10 0.2504  
cell 356  
2.84168E-08 0.1427  
cell 357  
3.64570E-10 0.3994  
cell 358  
2.19861E-08 0.1831  
cell 359  
4.99784E-10 0.3549  
cell 360  
2.79302E-08 0.1398  
cell 361  
1.73851E-10 0.8164  
cell 362  
2.27267E-08 0.1595  
cell 363  
7.62197E-10 0.2483  
cell 364  
2.49520E-08 0.1524  
cell 365  
7.06170E-10 0.2276  
cell 366  
2.41437E-08 0.1655  
cell 367  
4.50114E-10 0.3871  
cell 368  
2.49065E-08 0.1533  
cell 369  
1.63259E-10 0.8421  
cell 370

2.62744E-08 0.1361  
cell 371  
4.26180E-10 0.3443  
cell 372  
3.03354E-08 0.1155  
cell 373  
4.88497E-10 0.2922  
cell 374  
1.79180E-08 0.2030  
cell 375  
6.62358E-10 0.2263  
cell 376  
2.02818E-08 0.1859  
cell 377  
5.70792E-10 0.3012  
cell 378  
2.49213E-08 0.1479  
cell 379  
3.81853E-10 0.3103  
cell 380  
1.83853E-08 0.1881  
cell 381  
5.17216E-10 0.2833  
cell 382  
2.33239E-08 0.1437  
cell 383  
5.63549E-10 0.3020  
cell 384  
2.39616E-08 0.1412  
cell 385  
5.06513E-10 0.2818  
cell 386  
2.53259E-08 0.1431  
cell 387  
5.25647E-10 0.2899  
cell 388  
2.35554E-08 0.1477  
cell 389  
3.72290E-10 0.3462  
cell 390  
2.10901E-08 0.1629  
cell 391  
3.37702E-10 0.3923  
cell 392  
1.78592E-08 0.1788  
cell 393  
5.53965E-10 0.2657  
cell 394  
2.13407E-08 0.1576  
cell 395  
4.19981E-10 0.4123  
cell 396  
2.67075E-08 0.1284  
cell 397  
3.27337E-10 0.4366  
cell 398  
2.01932E-08 0.1662  
cell 399  
5.34532E-10 0.2767  
cell 400  
1.97695E-08 0.1675



cell 401  
6.02781E-10 0.2310  
cell 402  
2.28384E-08 0.1375  
cell 403  
5.95663E-10 0.2087  
cell 404  
2.02565E-08 0.1598  
cell 405  
6.22775E-10 0.2705  
cell 406  
2.70167E-08 0.1207  
cell 407  
6.57629E-10 0.2250  
cell 408  
1.63788E-08 0.1948  
cell 409  
7.34062E-10 0.1943  
cell 410  
2.26593E-08 0.1388  
cell 411  
6.81059E-10 0.2185  
cell 412  
2.42449E-08 0.1220  
cell 413  
8.88776E-10 0.2054  
cell 414  
2.00070E-08 0.1503  
cell 415  
5.90913E-10 0.2331  
cell 416  
2.31146E-08 0.1378  
cell 417  
6.22989E-10 0.2115  
cell 418  
2.70306E-08 0.1119  
cell 419  
4.44982E-10 0.2790  
cell 420  
2.00573E-08 0.1484  
cell 421  
9.77778E-10 0.1730  
cell 422  
2.25826E-08 0.1270  
cell 423  
1.06418E-09 0.1606  
cell 424  
2.72843E-08 0.1057  
cell 425  
6.76644E-10 0.2479  
cell 426  
2.14776E-08 0.1414  
cell 427  
6.80986E-10 0.2274  
cell 428  
1.74603E-08 0.1720  
cell 429  
7.31419E-10 0.2356  
cell 430  
1.86567E-08 0.1483  
cell 438

7.08223E-10 0.2112  
cell 439  
2.13237E-08 0.1239  
cell 440  
7.90651E-10 0.1746  
cell 441  
1.81075E-08 0.1593  
cell 442  
8.84656E-10 0.1899  
cell 443  
2.40281E-08 0.1169  
cell 444  
7.40936E-10 0.2213  
cell 445  
2.13231E-08 0.1336  
cell 446  
7.55079E-10 0.1955  
cell 447  
1.84425E-08 0.1570  
cell 448  
1.11674E-09 0.1711  
cell 449  
1.73093E-08 0.1500  
cell 450  
9.20481E-10 0.2042  
cell 450  
9.20481E-10 0.2042  
cell 451  
2.31642E-08 0.1191  
cell 452  
4.95095E-10 0.2932  
cell 453  
2.18239E-08 0.1232  
cell 454  
9.49303E-10 0.1704  
cell 455  
2.21819E-08 0.1255  
cell 456  
5.64355E-10 0.2817  
cell 457  
2.13288E-08 0.1205  
cell 458  
7.97755E-10 0.2137  
cell 459  
1.92886E-08 0.1337  
cell 460  
1.02097E-09 0.1686  
cell 461  
1.75823E-08 0.1449  
cell 462  
1.04479E-09 0.1615  
cell 463  
2.06673E-08 0.1280  
cell 464  
7.77093E-10 0.1729  
cell 465  
2.03200E-08 0.1296  
cell 466  
6.58274E-10 0.2253  
cell 467  
1.82007E-08 0.1375

cell 468  
7.79825E-10 0.2015  
cell 469  
2.05365E-08 0.1175  
cell 470  
8.03849E-10 0.2037  
cell 471  
1.55842E-08 0.1626  
cell 472  
9.44060E-10 0.1636  
cell 473  
2.20907E-08 0.1159  
cell 474  
1.01090E-09 0.1794  
cell 475  
1.43933E-08 0.1761  
cell 476  
8.30673E-10 0.1986  
cell 477  
1.98894E-08 0.1199  
cell 478  
5.24943E-10 0.3044  
cell 479  
1.72725E-08 0.1316  
cell 480  
9.27430E-10 0.1750  
cell 481  
1.79732E-08 0.1341  
cell 482  
1.10684E-09 0.1445  
cell 483  
1.91239E-08 0.1245  
cell 484  
1.29129E-09 0.1659  
cell 485  
1.18077E-08 0.2080  
cell 486  
7.39617E-10 0.1809  
cell 487  
1.39640E-08 0.1690  
cell 488  
8.43592E-10 0.1562  
cell 489  
1.68490E-08 0.1333  
cell 490  
1.15181E-09 0.1440  
cell 491  
1.66543E-08 0.1408  
cell 492  
8.05403E-10 0.2018  
cell 493  
1.81519E-08 0.1251  
cell 494  
9.86328E-10 0.1727  
cell 495  
1.59628E-08 0.1467  
cell 496  
8.67984E-10 0.1714  
cell 497  
1.93092E-08 0.1163  
cell 498

7.54682E-10 0.1511  
cell 499  
1.74509E-08 0.1277  
cell 500  
7.92763E-10 0.1890  
cell 501  
1.39295E-08 0.1607  
cell 502  
1.02142E-09 0.1465  
cell 503  
1.90288E-08 0.1203  
cell 504  
6.35929E-10 0.2068  
cell 505  
2.15095E-08 0.1060  
cell 506  
8.84261E-10 0.1699  
cell 507  
1.67079E-08 0.1267  
cell 508  
7.55150E-10 0.1794  
cell 509  
1.42038E-08 0.1480  
cell 510  
8.90660E-10 0.1781  
cell 511  
1.61881E-08 0.1380  
cell 512  
8.62736E-10 0.1678  
cell 513  
1.56059E-08 0.1393  
cell 514  
9.02816E-10 0.1747  
cell 515  
1.38195E-08 0.1626  
cell 516  
6.96170E-10 0.1670  
cell 517  
1.44118E-08 0.1410  
cell 518  
7.26930E-10 0.2551  
cell 519  
1.56775E-08 0.1280  
cell 520  
9.61808E-10 0.1796  
cell 521  
1.21332E-08 0.1745  
cell 522  
9.25841E-10 0.1562  
cell 523  
1.16918E-08 0.1841  
cell 524  
8.51887E-10 0.1900  
cell 525  
1.70039E-08 0.1234  
cell 526  
7.62229E-10 0.1621  
cell 527  
1.56861E-08 0.1291  
cell 528  
8.98189E-10 0.1642

cell 529  
1.43090E-08 0.1414  
cell 530  
9.51558E-10 0.1699  
cell 531  
1.88472E-08 0.1120  
cell 532  
7.78272E-10 0.1678  
cell 533  
1.07235E-08 0.1961  
cell 534  
1.02457E-09 0.1402  
cell 535  
1.58944E-08 0.1262  
cell 536  
8.99720E-10 0.1569  
cell 537  
1.38238E-08 0.1467  
cell 538  
6.36126E-10 0.2276  
cell 539  
1.34439E-08 0.1452  
cell 540  
6.68212E-10 0.2030  
cell 541  
1.67256E-08 0.1151  
cell 542  
7.88191E-10 0.1857  
cell 543  
1.36371E-08 0.1544  
cell 544  
6.62737E-10 0.2336  
cell 545  
1.42224E-08 0.1370  
cell 546  
4.64221E-10 0.2178  
cell 547  
1.55049E-08 0.1207  
cell 548  
8.06071E-10 0.1523  
cell 549  
1.44246E-08 0.1287  
cell 550  
8.59650E-10 0.1784  
cell 551  
1.26581E-08 0.1523  
cell 552  
7.43287E-10 0.2058  
cell 553  
1.36345E-08 0.1421  
cell 554  
7.79828E-10 0.2099  
cell 555  
1.44581E-08 0.1317  
cell 556  
8.79618E-10 0.1783  
cell 557  
1.45399E-08 0.1234  
cell 558  
1.08477E-09 0.1599  
cell 559

1.39787E-08 0.1259  
cell 560  
5.89350E-10 0.2304  
cell 561  
1.28092E-08 0.1434  
cell 562  
6.91486E-10 0.2110  
cell 563  
1.44584E-08 0.1281  
cell 564  
1.10275E-09 0.1593  
cell 565  
1.38554E-08 0.1284  
cell 566  
8.46758E-10 0.1774  
cell 567  
1.57341E-08 0.1085  
cell 568  
7.75807E-10 0.1750  
cell 569  
1.40725E-08 0.1212  
cell 570  
6.52302E-10 0.1967  
cell 571  
1.22076E-08 0.1556  
cell 572  
7.32381E-10 0.1877  
cell 573  
1.53713E-08 0.1143  
cell 574  
7.80395E-10 0.1741  
cell 575  
1.25113E-08 0.1401  
cell 576  
8.16916E-10 0.1643  
cell 577  
1.15516E-08 0.1498  
cell 578  
7.73654E-10 0.1924  
cell 579  
1.24350E-08 0.1349  
cell 580  
7.55429E-10 0.2007  
cell 581  
1.11300E-08 0.1557  
cell 582  
6.59694E-10 0.1884  
cell 583  
1.27181E-08 0.1408  
cell 584  
9.27730E-10 0.1697  
cell 585  
1.29916E-08 0.1297  
cell 586  
9.87082E-10 0.1664  
cell 587  
7.80577E-09 0.2189  
cell 588  
5.65924E-10 0.2341  
cell 589  
1.24594E-08 0.1337

cell 590  
8.54663E-10 0.1803  
cell 591  
1.32080E-08 0.1229  
cell 592  
4.92758E-10 0.2095  
cell 593  
1.14348E-08 0.1492  
cell 594  
9.27093E-10 0.1688  
cell 595  
1.23719E-08 0.1388  
cell 596  
5.61888E-10 0.2415  
cell 597  
1.25301E-08 0.1344  
cell 598  
7.41553E-10 0.1947  
cell 599  
1.10944E-08 0.1366  
cell 600  
8.65163E-10 0.1904  
cell 601  
1.05522E-08 0.1467  
cell 602  
5.05926E-10 0.2098  
cell 603  
1.18343E-08 0.1365  
cell 604  
7.96386E-10 0.1753  
cell 605  
1.32279E-08 0.1173  
cell 606  
8.74903E-10 0.1953  
cell 607  
1.04828E-08 0.1456  
cell 608  
8.00202E-10 0.1766  
cell 609  
1.03478E-08 0.1491  
cell 610  
7.86642E-10 0.1614  
cell 611  
1.23510E-08 0.1237  
cell 612  
9.90682E-10 0.1753  
cell 613  
9.85168E-09 0.1518  
cell 614  
7.13463E-10 0.1843  
cell 615  
1.07146E-08 0.1451  
cell 616  
7.75236E-10 0.1660  
cell 617  
1.05903E-08 0.1444  
cell 618  
7.27202E-10 0.1793  
cell 619  
9.96684E-09 0.1486  
cell 620

5.74758E-10 0.2161  
cell 621  
1.32310E-08 0.1156  
cell 622  
7.22335E-10 0.2069  
cell 623  
8.80790E-09 0.1664  
cell 624  
5.77762E-10 0.2192  
cell 625  
7.93121E-09 0.1992  
cell 626  
9.07384E-10 0.1677  
cell 627  
1.04652E-08 0.1363  
cell 628  
7.40472E-10 0.2073  
cell 629  
7.66968E-09 0.1899  
cell 630  
7.03279E-10 0.2072  
cell 631  
9.32334E-09 0.1538  
cell 632  
9.80308E-10 0.1710  
cell 633  
8.30312E-09 0.1838  
cell 634  
6.24311E-10 0.2318  
cell 635  
9.77802E-09 0.1538  
cell 636  
6.67116E-10 0.2109  
cell 637  
8.07438E-09 0.1715  
cell 638  
6.68797E-10 0.1968  
cell 639  
9.41005E-09 0.1489  
cell 640  
6.72500E-10 0.2213  
cell 641  
9.76102E-09 0.1477  
cell 642  
4.84783E-10 0.2258  
cell 643  
8.12015E-09 0.1835  
cell 644  
6.72798E-10 0.2101  
cell 645  
8.87657E-09 0.1606  
cell 646  
7.45770E-10 0.1766  
cell 647  
8.87777E-09 0.1591  
cell 648  
3.32277E-10 0.2810  
cell 649  
7.15869E-09 0.1839  
cell 650  
5.37529E-10 0.2356



cell 651  
9.53157E-09 0.1447  
cell 652  
3.92599E-10 0.2183  
cell 653  
9.50066E-09 0.1484  
cell 654  
4.11897E-10 0.3049  
cell 655  
1.05954E-08 0.1295  
cell 656  
4.94158E-10 0.2320  
cell 657  
8.81547E-09 0.1648  
cell 658  
7.97754E-10 0.1910  
cell 659  
6.65305E-09 0.2055  
cell 660  
6.00458E-10 0.1793  
cell 661  
8.56252E-09 0.1500  
cell 662  
6.54928E-10 0.1975  
cell 663  
6.89169E-09 0.2010  
cell 664  
6.11663E-10 0.2267  
cell 665  
8.29812E-09 0.1618  
cell 666  
5.28714E-10 0.2328  
cell 667  
5.82713E-09 0.2272  
cell 668  
3.97955E-10 0.3032  
cell 669  
8.84000E-09 0.1415  
cell 670  
5.23429E-10 0.2390  
cell 671  
6.84141E-09 0.1941  
cell 672  
6.29799E-10 0.1892  
cell 673  
9.12697E-09 0.1385  
cell 674  
6.54125E-10 0.1824  
cell 675  
1.17401E-08 0.1119  
cell 676  
5.46896E-10 0.1912  
cell 677  
8.18843E-09 0.1563  
cell 678  
4.46247E-10 0.2812  
cell 679  
7.66660E-09 0.1596  
cell 680  
3.29531E-10 0.2952  
cell 681

9.47374E-09 0.1326  
cell 682  
4.73623E-10 0.2862  
cell 683  
8.11371E-09 0.1603  
cell 684  
3.93345E-10 0.2151  
cell 685  
7.72110E-09 0.1658  
cell 686  
6.05003E-10 0.1998  
cell 687  
7.00840E-09 0.1765  
cell 688  
7.14497E-10 0.1951  
cell 689  
5.93416E-09 0.2015  
cell 690  
5.81057E-10 0.2043  
cell 691  
7.02645E-09 0.1795  
cell 692  
5.02666E-10 0.2099  
cell 693  
8.67333E-09 0.1436  
cell 694  
4.72129E-10 0.2680  
cell 695  
6.17618E-09 0.1958  
cell 696  
7.16153E-10 0.1838  
cell 697  
8.42865E-09 0.1316  
cell 698  
5.35164E-10 0.2157  
cell 699  
7.15759E-09 0.1623  
cell 700  
5.36793E-10 0.231  
cell 701  
7.93359E-09 0.1577  
cell 702  
7.02212E-10 0.2039  
cell 703  
7.65027E-09 0.1647  
cell 704  
5.31447E-10 0.2246  
cell 705  
8.36032E-09 0.1438  
cell 706  
6.70411E-10 0.2056  
cell 707  
5.53061E-09 0.2155  
cell 708  
3.48549E-10 0.2818  
cell 709  
7.19610E-09 0.1504  
cell 710  
5.59455E-10 0.2667  
cell 711  
6.65557E-09 0.1929

cell 712  
4.78059E-10 0.2483  
cell 713  
6.38878E-09 0.1949  
cell 714  
6.50670E-10 0.2075  
cell 715  
7.93112E-09 0.1438  
cell 716  
4.44894E-10 0.2113  
cell 717  
9.50360E-09 0.1198  
cell 718  
6.95859E-10 0.1970  
cell 719  
7.48404E-09 0.1458  
cell 720  
5.47400E-10 0.2324  
cell 721  
6.54259E-09 0.1784  
cell 722  
7.77193E-10 0.1960  
cell 723  
6.10067E-09 0.1911  
cell 724  
4.01634E-10 0.2855  
cell 725  
5.66136E-09 0.2089  
cell 726  
5.38918E-10 0.2634  
cell 727  
6.44297E-09 0.1719  
cell 728  
4.25422E-10 0.2214  
cell 729  
5.41678E-09 0.2071  
cell 730  
4.39279E-10 0.2767  
cell 731  
5.82279E-09 0.1867  
cell 732  
6.68677E-10 0.2177  
cell 733  
7.35046E-09 0.1569  
cell 734  
3.94183E-10 0.2554  
cell 735  
7.24313E-09 0.1487  
cell 736  
4.15704E-10 0.2626  
cell 737  
6.02337E-09 0.1747  
cell 738  
4.47315E-10 0.2347  
cell 739  
6.30593E-09 0.1664  
cell 740  
6.35865E-10 0.2000  
cell 741  
5.28617E-09 0.2017  
cell 742

4.52986E-10 0.2736  
cell 743  
4.20163E-09 0.2631  
cell 744  
6.28359E-10 0.2007  
cell 745  
5.60780E-09 0.1898  
cell 746  
3.26352E-10 0.2494  
cell 747  
6.12360E-09 0.1740  
cell 748  
4.26777E-10 0.2377  
cell 749  
5.91607E-09 0.1748  
cell 750  
5.15301E-10 0.2443  
cell 751  
4.70864E-09 0.2322  
cell 752  
6.22603E-10 0.2255  
cell 753  
4.45476E-09 0.2410  
cell 754  
2.96114E-10 0.2946  
cell 755  
4.98047E-09 0.2133  
cell 756  
4.48265E-10 0.2198  
cell 757  
5.03954E-09 0.2109  
cell 758  
3.80949E-10 0.2977  
cell 759  
6.86266E-09 0.1464  
cell 760  
3.64861E-10 0.3056  
cell 761  
5.28300E-09 0.1897  
cell 762  
3.08014E-10 0.3452  
cell 763  
6.75919E-09 0.1553  
cell 764  
4.93430E-10 0.2537  
cell 765  
4.04862E-09 0.2729  
cell 766  
3.22790E-10 0.3853  
cell 767  
4.19753E-09 0.2494  
cell 768  
4.28499E-10 0.2548  
cell 769  
5.70221E-09 0.1821  
cell 770  
3.05005E-10 0.3255  
cell 771  
5.89340E-09 0.1719  
cell 772  
3.94530E-10 0.2597

cell 773  
5.09008E-09 0.2053  
cell 774  
5.93871E-10 0.2040  
cell 775  
6.96450E-09 0.1443  
cell 776  
2.97756E-10 0.3136  
cell 777  
6.60038E-09 0.1447  
cell 778  
3.22503E-10 0.2678  
cell 779  
6.53242E-09 0.1491  
cell 780  
3.38165E-10 0.2819  
cell 781  
5.35633E-09 0.1806  
cell 782  
3.54633E-10 0.3326  
cell 783  
4.91355E-09 0.2156  
cell 784  
3.72854E-10 0.2474  
cell 785  
3.84998E-09 0.2465  
cell 786  
5.58339E-10 0.2325  
cell 787  
5.83208E-09 0.1506  
cell 788  
2.19362E-10 0.2895  
cell 789  
3.98979E-09 0.2227  
cell 790  
3.70666E-10 0.2703  
cell 791  
5.27244E-09 0.1802  
cell 792  
4.60945E-10 0.2700  
cell 793  
4.29081E-09 0.2227  
cell 794  
4.60978E-10 0.2269  
cell 795  
6.05145E-09 0.1578  
cell 796  
3.69119E-10 0.2465  
cell 797  
3.29916E-09 0.2873  
cell 798  
4.24792E-10 0.2768  
cell 799  
4.02106E-09 0.2412  
cell 800  
2.30036E-10 0.3017  
cell 801  
5.66442E-09 0.1758  
cell 802  
3.66076E-10 0.3028  
cell 803

	5.13792E-09	0.1751
cell 804		
	4.78647E-10	0.2140
cell 805		
	3.72178E-09	0.2416
cell 806		
	7.07048E-10	0.1989
cell union total		
	5.38516E-05	0.0071